

#### **TEST REPORT**

2603 - 12th Street, SE Salem, OR 97302 Voice: (503) 363-0473 FAX: (503) 363-8900

**TO: Community Action Head Start** 

2475 Center ST NE Salem, OR 97301 07/10/2017

COMACTHS

PO#: 24962

Collection Information

Date: 06/14/2017 Time: 0830

By: T Schueller-Pedro

Lab #:

20170620-033

Location: Gracies Place #5 adult sink

Lab Receipt Information

06/20/2017 1101

RD.

# Case Narrative

The analyses were performed according to the guidelines in the WATERLAB Corp Quality Assurance Program. This report contains analytical results for the sample(s) as received by the laboratory.

WATERLAB Corp certifies that this report is in compliance with the requirements of NELAC. No unusual difficulties were experienced during analysis of this batch except as noted below or qualified with data flags on the reports.

	•						EPA	Analys	is
Analyte	Method	Acc*	Results	Qual	MRL	Units	Limit	Date Time	Tech
Lead Schools/Bldgs	SM3113 B	Α	0.0018		0.001	mg/l	0.020	06/26/2017	BEM

ND- No Detection at @ MRL SM-"Standard Methods for the Examination of Water & Wastewater",19th ed EPA- "Methods for Chemical Analysis for Water and Wastes",USEPA MRL-"Method Reporting Limit" \* Accreditation A- Waterlab Corporation, ORELAP 100039 The results relate only to the parameters tested or to the sample as received by the laboratory.

	1/2
Approved by:	100



## **TEST REPORT**

2603 - 12th Street, SE Salem, OR 97302 Voice: (503) 363-0473 FAX: (503) 363-8900

**TO: Community Action Head Start** 

2475 Center ST NE Salem, OR 97301 07/10/2017

COMACTHS

PO#: 24962

**Collection Information** 

Date: 06/14/2017 Time: 0830

By: T Schueller-Pedro

Lab #: 20170620-034

Location: Gracies Place #5 child sink R

Lab Receipt Information

06/20/2017 1101

RD

# Case Narrative

The analyses were performed according to the guidelines in the WATERLAB Corp Quality Assurance Program. This report contains analytical results for the sample(s) as received by the laboratory.

WATERLAB Corp certifies that this report is in compliance with the requirements of NELAC. No unusual difficulties were experienced during analysis of this batch except as noted below or qualified with data flags on the reports.

-								Analysis	
Analyte	Method	Acc	* Results	Qual	MRL	Units	Limit*	Date Time	Tech
Lead Schools/Bidgs	SM3113 B	Α	0.0022		0.001	mg/l	0.020	06/29/2017	BEM

ND- No Detection at @ MRL SM-"Standard Methods for the Examination of Water & Wastewater",19th ed EPA- "Methods for Chemical Analysis for Water and Wastes",USEPA MRL-"Method Reporting Limit" \* Accreditation A- Waterlab Corporation, ORELAP 100039

The results relate only to the parameters tested or to the sample as received by the laboratory.

4 - 0	1/2
Approved by:	1 / R
• • • • • • • • • • • • • • • • • • • •	

## **TEST REPORT**

2603 - 12th Street, SE Salem, OR 97302 Voice: (503) 363-0473 FAX: (503) 363-8900

TO: Community Action Head Start

2475 Center ST NE Salem, OR 97301 07/10/2017

COMACTHS

PO#: 24962

Collection Information

Date: 06/14/2017 Time: 0830

By: T Schueller-Pedro Lab #: 20170620-035

Location: Gracies Place #5 child sink L

Lab Receipt Information 06/20/2017

1101 RD

## **Case Narrative**

The analyses were performed according to the guidelines in the WATERLAB Corp Quality Assurance Program. This report contains analytical results for the sample(s) as received by the laboratory.

WATERLAB Corp certifies that this report is in compliance with the requirements of NELAC. No unusual difficulties were experienced during analysis of this batch except as noted below or qualified with data flags on the reports.

							EPA	Analysis	
Analyte	Method	Acc	* Results	Qual	MRL	Units	Limit	Date Time	Tech
Lead Schools/Bldgs	SM3113 B	Α	0.0013		0.001	mg/l	0.020	06/29/2017	BEM

ND- No Detection at @ MRL SM-"Standard Methods for the Examination of Water & Wastewater",19th ed EPA- "Methods for Chemical Analysis for Water and Wastes",USEPA MRL-"Method Reporting Limit"

\* Accreditation

A- Waterlab Corporation, ORELAP 100039 The results relate only to the parameters tested or to the sample as received by the laboratory.

Approved by:	<u> </u>

#### **TEST REPORT**

2603 - 12th Street, SE Salem, OR 97302 Voice: (503) 363-0473 FAX: (503) 363-8900

**TO: Community Action Head Start** 

2475 Center ST NE Salem, OR 97301 07/10/2017

**COMACTHS** 

PO#: 24962

**Collection Information** 

Date: 06/14/2017 Time: 0830

By: T So

T Schueller-Pedro 20170620-036

Location:

Lab #:

Gracies Place kitchen

Lab Receipt Information

06/20/2017 1101

RD

## **Case Narrative**

The analyses were performed according to the guidelines in the WATERLAB Corp Quality Assurance Program. This report contains analytical results for the sample(s) as received by the laboratory.

WATERLAB Corp certifies that this report is in compliance with the requirements of NELAC. No unusual difficulties were experienced during analysis of this batch except as noted below or qualified with data flags on the reports.

-							EPA	Analysis	
Analyte	Method	Acc	* Results	Qual	MRL	Units	Limit	Date Time	Tech
Lead Schools/Bldgs	SM3113 B	Α	ND		0.001	mg/l	0.020	06/29/2017	ВЕМ

ND- No Detection at @ MRL
SM-"Standard Methods for the Examination of Water & Wastewater",19th ed
EPA- "Methods for Chemical Analysis for Water and Wastes",USEPA
MRL-"Method Reporting Limit"
\* Accreditation
A- Waterlab Corporation, ORELAP 100039

The results relate only to the parameters tested or to the sample as received by the laboratory.

	12
Approved by:	
	,

## **TEST REPORT**

2603 - 12th Street, SE Salem, OR 97302 Voice: (503) 363-0473 FAX: (503) 363-8900

**TO: Community Action Head Start** 

2475 Center ST NE Salem, OR 97301

07/10/2017

COMACTHS

PO#: 24962

**Collection Information** 

Date: 06/14/2017 Time: 0830

By: T Schueller Pedro

20170620-037 Lab #:

Gracies Place #6 adult sink Location:

Lab Receipt Information

06/20/2017 1101

RD

## **Case Narrative**

The analyses were performed according to the guidelines in the WATERLAB Corp Quality Assurance Program. This report contains analytical results for the sample(s) as received by the laboratory.

2 WATERLAB Corp certifies that this report is in compliance with the requirements of NELAC. No unusual difficulties were experienced during analysis of this batch except as noted below or qualified with data flags on the reports.

•							EPA	. Analys	is
Analyte	Method	Acc	* Results	Qual	MRL	Units	Limit	Date Time	Tech
Lead Schools/Bldgs	SM3113 B	Α	0.0024		0.001	mg/l	0.020	06/29/2017	ВЕМ

ND- No Detection at @ MRL SM-"Standard Methods for the Examination of Water & Wastewater",19th ed EPA- "Methods for Chemical Analysis for Water and Wastes", USEPA MRL-"Method Reporting Limit"

A- Waterlab Corporation, ORELAP 100039

The results relate only to the parameters tested or to the sample as received by the laboratory.

This report shall not be reproduced except in full, without the written approval of Waterlab Corporation.

Approved by:

\* Accreditation

#### **TEST REPORT**

2603 - 12th Street, SE Salem, OR 97302 Voice: (503) 363-0473 FAX: (503) 363-8900

**TO: Community Action Head Start** 

2475 Center ST NE Salem, OR 97301

07/10/2017

COMACTHS

PO#: 24962

**Collection Information** 

Date: 06/14/2017 Time: 0830

By: T Schueller-Pedro

Lab #:

20170620-038

Location:

Gracies Place #6 child sink L

Lab Receipt Information

06/20/2017

1101 RD

#### **Case Narrative**

The analyses were performed according to the guidelines in the WATERLAB Corp Quality Assurance Program. This report contains analytical results for the sample(s) as received by the laboratory.

WATERLAB Corp certifies that this report is in compliance with the requirements of NELAC. No unusual difficulties were experienced during analysis of this batch except as noted below or qualified with data flags on the reports.

•							EPA	Analys	is
Analyte	Method	Acc'	* Results	Qual	MRL	Units	Limit	Date Time	Tech
Lead Schools/Bldgs	SM3113 B	Α	0.0023		0.001	mg/l	0.020	06/29/2017	BEM

ND- No Detection at @ MRL SM-"Standard Methods for the Examination of Water & Wastewater",19th ed EPA- "Methods for Chemical Analysis for Water and Wastes", USEPA MRL-"Method Reporting Limit" \* Accreditation A- Waterlab Corporation, ORELAP 100039

The results relate only to the parameters tested or to the sample as received by the laboratory.

•	Mr.
Approved by:	



## TEST REPORT

2603 - 12th Street, SE Salem, OR 97302 Voice: (503) 363-0473 FAX: (503) 363-8900

**TO: Community Action Head Start** 

2475 Center ST NE Salem, OR 97301

07/10/2017

COMACTHS

PO#: 24962

**Collection Information** 

Date: 06/14/2017 Time: 0830

T Schueller-Pedro By:

20170620-039 Lab #: Location:

Gracies Place #6 child sink R

Lab Receipt Information

06/20/2017 1101

RD

## Case Narrative

The analyses were performed according to the guidelines in the WATERLAB Corp Quality Assurance Program. This report contains analytical results for the sample(s) as received by the laboratory.

WATERLAB Corp certifies that this report is in compliance with the requirements of NELAC. No unusual difficulties were experienced during analysis of this batch except as noted below or qualified with data flags on the reports.

•							EPA	Analys	is
Analyte	Method	Acc'	* Results	Qual	MRL	Units	Limit	Date Time	Tech
Lead Schools/Bidgs	SM3113 B	Α	0.0022		0.001	mg/l	0.020	06/29/2017	BEM

ND- No Detection at @ MRL SM-"Standard Methods for the Examination of Water & Wastewater",19th ed EPA- "Methods for Chemical Analysis for Water and Wastes", USEPA MRL-"Method Reporting Limit" \* Accreditation A- Waterlab Corporation, ORELAP 100039 The results relate only to the parameters tested or to the sample as received by

the laboratory.

•	Be
Approved by:	120