

## TEST REPORT

2603 - 12th Street, SE  
Salem, OR 97302  
Voice: (503) 363-0473  
FAX: (503) 363-8900

TO: Family Building Blocks / Heather Peasley  
180 18th St NE  
Salem, OR 97301

06/11/2018

FAMBUI

PO#:

### Collection Information

Date: 05/25/2018  
Time: 0711  
By: Heather  
Lab #: 20180525-046  
Location: water fountain (CP)

### Lab Receipt Information

05/25/2018  
1357  
RD

### Case Narrative

The analyses were performed according to the guidelines in the WATERLAB Corp Quality Assurance Program. This report contains analytical results for the sample(s) as received by the laboratory.

WATERLAB Corp certifies that this report is in compliance with the requirements of NELAC. No unusual difficulties were experienced during analysis of this batch except as noted below or qualified with data flags on the reports.

Analyte	Method	Acc*	Results	Qual	MRL	Units	EPA Limit	Analysis	
								Date	Time
Lead Schools/Bldgs	SM3113 B	A	ND		0.001	mg/l	0.020	06/08/2018	BEM

ND- No Detection at @ MRL

SM-"Standard Methods for the Examination of Water & Wastewater", 19th ed

EPA- "Methods for Chemical Analysis for Water and Wastes", USEPA

MRL-"Method Reporting Limit"

\* Accreditation

A- Waterlab Corporation, ORELAP 100039

The results relate only to the parameters tested or to the sample as received by the laboratory.

This report shall not be reproduced except in full, without the written approval of Waterlab Corporation.

Approved by: \_\_\_\_\_



## TEST REPORT

**TO: Family Building Blocks / Heather Peasley**  
180 18th St NE  
Salem, OR 97301

06/11/2018

FAMBUI

PO#:

### Collection Information

Date: 05/25/2018  
Time: 0709  
By: Heather  
Lab #: 20180525-045  
Location: kitchen (CP)

### Lab Receipt Information

05/25/2018  
1357  
RD

### Case Narrative

The analyses were performed according to the guidelines in the WATERLAB Corp Quality Assurance Program. This report contains analytical results for the sample(s) as received by the laboratory.

WATERLAB Corp certifies that this report is in compliance with the requirements of NELAC. No unusual difficulties were experienced during analysis of this batch except as noted below or qualified with data flags on the reports.

Analyte	Method	Acc*	Results	Qual	MRL	Units	EPA Limit	Analysis	
								Date	Time
Lead Schools/Bldgs	SM3113 B	A	ND		0.001	mg/l	0.020	06/08/2018	BEM

ND- No Detection at @ MRL

SM-"Standard Methods for the Examination of Water & Wastewater", 19th ed

EPA- "Methods for Chemical Analysis for Water and Wastes", USEPA

MRL-"Method Reporting Limit"

\* Accreditation

A- Waterlab Corporation, ORELAP 100039

The results relate only to the parameters tested or to the sample as received by the laboratory.

This report shall not be reproduced except in full, without the written approval of Waterlab Corporation.

Approved by: \_\_\_\_\_



## TEST REPORT

TO: Family Building Blocks / Heather Peasley  
180 18th St NE  
Salem, OR 97301

06/11/2018

FAMBUI

PO#:

### Collection Information

Date: 05/25/2018  
Time: 0718  
By: Heather  
Lab #: 20180525-044  
Location: classroom 4

### Lab Receipt Information

05/25/2018  
1357  
RD

### Case Narrative

The analyses were performed according to the guidelines in the WATERLAB Corp Quality Assurance Program. This report contains analytical results for the sample(s) as received by the laboratory.

WATERLAB Corp certifies that this report is in compliance with the requirements of NELAC. No unusual difficulties were experienced during analysis of this batch except as noted below or qualified with data flags on the reports.

Analyte	Method	Acc*	Results	Qual	MRL	Units	EPA Limit	Analysis	
								Date	Time
Lead Schools/Bldgs	SM3113 B	A	0.0022		0.001	mg/l	0.020	06/08/2018	BEM

ND- No Detection at @ MRL

SM-"Standard Methods for the Examination of Water & Wastewater", 19th ed

EPA- "Methods for Chemical Analysis for Water and Wastes", USEPA

MRL-"Method Reporting Limit"

\* Accreditation

A- Waterlab Corporation, ORELAP 100039

The results relate only to the parameters tested or to the sample as received by the laboratory.

This report shall not be reproduced except in full, without the written approval of Waterlab Corporation.

Approved by: \_\_\_\_\_



## TEST REPORT

**TO: Family Building Blocks / Heather Peasley**  
180 18th St NE  
Salem, OR 97301

06/11/2018

FAMBUI

PO#:

### Collection Information

Date: 05/25/2018  
Time: 0716  
By: Heather  
Lab #: 20180525-043  
Location: classroom 3

### Lab Receipt Information

05/25/2018  
1357  
RD

### Case Narrative

The analyses were performed according to the guidelines in the WATERLAB Corp Quality Assurance Program. This report contains analytical results for the sample(s) as received by the laboratory.

WATERLAB Corp certifies that this report is in compliance with the requirements of NELAC. No unusual difficulties were experienced during analysis of this batch except as noted below or qualified with data flags on the reports.

Analyte	Method	Acc*	Results	Qual	MRL	Units	EPA	Analysis	
							Limit	Date	Time
Lead Schools/Bldgs	SM3113 B	A	ND		0.001	mg/l	0.020	06/08/2018	BEM

ND- No Detection at @ MRL

SM-"Standard Methods for the Examination of Water & Wastewater", 19th ed

EPA- "Methods for Chemical Analysis for Water and Wastes", USEPA

MRL-"Method Reporting Limit"

\* Accreditation

A- Waterlab Corporation, ORELAP 100039

The results relate only to the parameters tested or to the sample as received by the laboratory.

This report shall not be reproduced except in full, without the written approval of Waterlab Corporation.

Approved by: \_\_\_\_\_



## TEST REPORT

TO: Family Building Blocks / Heather Peasley  
180 18th St NE  
Salem, OR 97301

06/11/2018  
FAMBUI

PO#:

### Collection Information

Date: 05/25/2018  
Time: 0714  
By: Heather  
Lab #: 20180525-042  
Location: classroom 2

### Lab Receipt Information

05/25/2018  
1357  
RD

### Case Narrative

The analyses were performed according to the guidelines in the WATERLAB Corp Quality Assurance Program. This report contains analytical results for the sample(s) as received by the laboratory.

WATERLAB Corp certifies that this report is in compliance with the requirements of NELAC. No unusual difficulties were experienced during analysis of this batch except as noted below or qualified with data flags on the reports.

Analyte	Method	Acc*	Results	Qual	MRL	Units	EPA Limit	Analysis	
								Date	Time
Lead Schools/Bldgs	SM3113 B	A	ND		0.001	mg/l	0.020	06/08/2018	BEM

ND- No Detection at @ MRL

SM-"Standard Methods for the Examination of Water & Wastewater", 19th ed

EPA- "Methods for Chemical Analysis for Water and Wastes", USEPA

MRL-"Method Reporting Limit"

\* Accreditation

A- Waterlab Corporation, ORELAP 100039

The results relate only to the parameters tested or to the sample as received by the laboratory.

This report shall not be reproduced except in full, without the written approval of Waterlab Corporation.

Approved by: \_\_\_\_\_



## TEST REPORT

TO: Family Building Blocks / Heather Peasley  
180 18th St NE  
Salem, OR 97301

06/11/2018  
FAMBUI

PO#:

### Collection Information

Date: 05/25/2018  
Time: 0712  
By: Heather  
Lab #: 20180525-041  
Location: classroom 1

### Lab Receipt Information

05/25/2018  
1357  
RD

### Case Narrative

The analyses were performed according to the guidelines in the WATERLAB Corp Quality Assurance Program. This report contains analytical results for the sample(s) as received by the laboratory.

WATERLAB Corp certifies that this report is in compliance with the requirements of NELAC. No unusual difficulties were experienced during analysis of this batch except as noted below or qualified with data flags on the reports.

Analyte	Method	Acc*	Results	Qual	MRL	Units	EPA	Analysis	Tech
							Limit	Date Time	
Lead Schools/Bldgs	SM3113 B	A	ND		0.001	mg/l	0.020	06/08/2018	BEM

ND- No Detection at @ MRL

SM-"Standard Methods for the Examination of Water & Wastewater", 19th ed

EPA- "Methods for Chemical Analysis for Water and Wastes", USEPA

MRL-"Method Reporting Limit"

\* Accreditation

A- Waterlab Corporation, ORELAP 100039

The results relate only to the parameters tested or to the sample as received by the laboratory.

This report shall not be reproduced except in full, without the written approval of Waterlab Corporation.

Approved by: \_\_\_\_\_

