

TEST REPORT

TO: Community Action Head Start
2475 Center ST NE
Salem, OR 97301

07/06/2017

COMACTHS

PO#: 24962

Collection Information

Date: 06/15/2017
Time: 0715
By: Salinas/Kelley
Lab #: 20170620-049
Location: MG 11

Lab Receipt Information

06/20/2017
1101
RD

Case Narrative

The analyses were performed according to the guidelines in the WATERLAB Corp Quality Assurance Program. This report contains analytical results for the sample(s) as received by the laboratory.

WATERLAB Corp certifies that this report is in compliance with the requirements of NELAC. No unusual difficulties were experienced during analysis of this batch except as noted below or qualified with data flags on the reports.

Analyte	Method	Acc*	Results	Qual	MRL	Units	EPA Limit	Analysis	
								Date	Time
Lead Schools/Bldgs	SM3113 B	A	ND		0.001	mg/l	0.020	06/29/2017	BEM

ND- No Detection at @ MRL

SM-"Standard Methods for the Examination of Water & Wastewater", 19th ed

EPA- "Methods for Chemical Analysis for Water and Wastes", USEPA

MRL-"Method Reporting Limit"

* Accreditation

A- Waterlab Corporation, ORELAP 100039

The results relate only to the parameters tested or to the sample as received by the laboratory.

This report shall not be reproduced except in full, without the written approval of Waterlab Corporation.

Approved by: _____



TEST REPORT

TO: Community Action Head Start
2475 Center ST NE
Salem, OR 97301

07/06/2017

COMACTHS

PO#: 24962

Collection Information

Date: 06/15/2017
Time: 0715
By: Salinas/Kelley
Lab #: 20170620-050
Location: MG 12

Lab Receipt Information

06/20/2017
1101
RD

Case Narrative

The analyses were performed according to the guidelines in the WATERLAB Corp Quality Assurance Program. This report contains analytical results for the sample(s) as received by the laboratory.

WATERLAB Corp certifies that this report is in compliance with the requirements of NELAC. No unusual difficulties were experienced during analysis of this batch except as noted below or qualified with data flags on the reports.

Analyte	Method	Acc*	Results	Qual	MRL	Units	EPA Limit	Analysis	
								Date	Time
Lead Schools/Bldgs	SM3113 B	A	ND		0.001	mg/l	0.020	06/29/2017	BEM

ND- No Detection at @ MRL

SM-"Standard Methods for the Examination of Water & Wastewater", 19th ed

EPA- "Methods for Chemical Analysis for Water and Wastes", USEPA

MRL-"Method Reporting Limit"

* Accreditation

A- Waterlab Corporation, ORELAP 100039

The results relate only to the parameters tested or to the sample as received by the laboratory.

This report shall not be reproduced except in full, without the written approval of Waterlab Corporation.

Approved by: _____



TEST REPORT

TO: Community Action Head Start
2475 Center ST NE
Salem, OR 97301

07/06/2017

COMACTHS

PO#: 24962

Collection Information

Date: 06/15/2017
Time: 0715
By: Salinas/Kelley
Lab #: 20170620-051
Location: MG 73

Lab Receipt Information

06/20/2017
1101
RD

Case Narrative

The analyses were performed according to the guidelines in the WATERLAB Corp Quality Assurance Program. This report contains analytical results for the sample(s) as received by the laboratory.

WATERLAB Corp certifies that this report is in compliance with the requirements of NELAC. No unusual difficulties were experienced during analysis of this batch except as noted below or qualified with data flags on the reports.

Analyte	Method	Acc*	Results	Qual	MRL	Units	EPA Limit	Analysis	
								Date	Time
Lead Schools/Bldgs	SM3113 B	A	ND		0.001	mg/l	0.020	06/29/2017	BEM

ND- No Detection at @ MRL

SM-"Standard Methods for the Examination of Water & Wastewater", 19th ed

EPA- "Methods for Chemical Analysis for Water and Wastes", USEPA

MRL-"Method Reporting Limit"

* Accreditation

A- Waterlab Corporation, ORELAP 100039

The results relate only to the parameters tested or to the sample as received by the laboratory.

This report shall not be reproduced except in full, without the written approval of Waterlab Corporation.

Approved by: _____



TEST REPORT

TO: Community Action Head Start
2475 Center ST NE
Salem, OR 97301

07/06/2017
COMACTHS

PO#: 24962

Collection Information

Date: 06/15/2017
Time: 0717
By: Salinas/Kelley
Lab #: 20170620-052
Location: MG prep

Lab Receipt Information

06/20/2017
1101
RD

Case Narrative

The analyses were performed according to the guidelines in the WATERLAB Corp Quality Assurance Program. This report contains analytical results for the sample(s) as received by the laboratory.

WATERLAB Corp certifies that this report is in compliance with the requirements of NELAC. No unusual difficulties were experienced during analysis of this batch except as noted below or qualified with data flags on the reports.

Analyte	Method	Acc*	Results	Qual	MRL	Units	EPA Limit	Analysis	
								Date	Time
Lead Schools/Bldgs	SM3113 B	A	0.0025		0.001	mg/l	0.020	06/29/2017	BEM

ND- No Detection at @ MRL

SM-"Standard Methods for the Examination of Water & Wastewater", 19th ed

EPA- "Methods for Chemical Analysis for Water and Wastes", USEPA

MRL-"Method Reporting Limit"

* Accreditation

A- Waterlab Corporation, ORELAP 100039

The results relate only to the parameters tested or to the sample as received by the laboratory.

This report shall not be reproduced except in full, without the written approval of Waterlab Corporation.

Approved by: _____



TEST REPORT

TO: Community Action Head Start
2475 Center ST NE
Salem, OR 97301

07/10/2017

COMACTHS

PO#: 24962

Collection Information

Lab Receipt Information

Date: 06/14/2017
Time: 0755
By: Salinas/Kelley
Lab #: 20170620-053
Location: MG 6

06/20/2017
1101
RD

Case Narrative

The analyses were performed according to the guidelines in the WATERLAB Corp Quality Assurance Program. This report contains analytical results for the sample(s) as received by the laboratory.

WATERLAB Corp certifies that this report is in compliance with the requirements of NELAC. No unusual difficulties were experienced during analysis of this batch except as noted below or qualified with data flags on the reports.

Analyte	Method	Acc*	Results	Qual	MRL	Units	EPA Limit	Analysis	
								Date	Time
Lead Schools/Bldgs	SM3113 B	A	0.0046		0.001	mg/l	0.020	06/29/2017	BEM

ND- No Detection at @ MRL

SM-"Standard Methods for the Examination of Water & Wastewater", 19th ed

EPA- "Methods for Chemical Analysis for Water and Wastes", USEPA

MRL-"Method Reporting Limit"

* Accreditation

A- Waterlab Corporation, ORELAP 100039

The results relate only to the parameters tested or to the sample as received by the laboratory.

This report shall not be reproduced except in full, without the written approval of Waterlab Corporation.

Approved by: 

TEST REPORT

TO: Community Action Head Start
2475 Center ST NE
Salem, OR 97301

07/10/2017
COMACTHS

PO#: 24962

Collection Information

Date: 06/14/2017
Time: 0757
By: Salinas/Kelley
Lab #: 20170620-054
Location: MG FDFY

Lab Receipt Information

06/20/2017
1101
RD

Case Narrative

The analyses were performed according to the guidelines in the WATERLAB Corp Quality Assurance Program. This report contains analytical results for the sample(s) as received by the laboratory.

WATERLAB Corp certifies that this report is in compliance with the requirements of NELAC. No unusual difficulties were experienced during analysis of this batch except as noted below or qualified with data flags on the reports.

Analyte	Method	Acc*	Results	Qual	MRL	Units	EPA Limit	Analysis	
								Date	Time
Lead Schools/Bldgs	SM3113 B	A	0.0051		0.001	mg/l	0.020	06/29/2017	BEM

ND- No Detection at @ MRL

SM-"Standard Methods for the Examination of Water & Wastewater", 19th ed

EPA- "Methods for Chemical Analysis for Water and Wastes", USEPA

MRL-"Method Reporting Limit"

* Accreditation

A- Waterlab Corporation, ORELAP 100039

The results relate only to the parameters tested or to the sample as received by the laboratory.

This report shall not be reproduced except in full, without the written approval of Waterlab Corporation.

Approved by: 

TEST REPORT

TO: Community Action Head Start
2475 Center ST NE
Salem, OR 97301

07/10/2017

COMACTHS

PO#: 24962

Collection Information

Date: 06/14/2017
Time: 0758
By: Salinas/Kelley
Lab #: 20170620-056
Location: MG 3

Lab Receipt Information

06/20/2017
1101
RD

Case Narrative

The analyses were performed according to the guidelines in the WATERLAB Corp Quality Assurance Program. This report contains analytical results for the sample(s) as received by the laboratory.

WATERLAB Corp certifies that this report is in compliance with the requirements of NELAC. No unusual difficulties were experienced during analysis of this batch except as noted below or qualified with data flags on the reports.

Analyte	Method	Acc*	Results	Qual	MRL	Units	EPA Limit	Analysis	
								Date	Time
Lead Schools/Bldgs	SM3113 B	A	ND		0.001	mg/l	0.020	06/29/2017	BEM

ND- No Detection at @ MRL

SM-"Standard Methods for the Examination of Water & Wastewater", 19th ed

EPA- "Methods for Chemical Analysis for Water and Wastes", USEPA

MRL-"Method Reporting Limit"

* Accreditation

A- Waterlab Corporation, ORELAP 100039

The results relate only to the parameters tested or to the sample as received by the laboratory.

This report shall not be reproduced except in full, without the written approval of Waterlab Corporation.

Approved by: _____



TEST REPORT

TO: Community Action Head Start
2475 Center ST NE
Salem, OR 97301

07/10/2017
COMACTHS

PO#: 24962

Collection Information

Date: 06/14/2017
Time: 0802
By: Salinas/Kelley
Lab #: 20170620-057
Location: MG 3 (U)

Lab Receipt Information

06/20/2017
1101
RD

Case Narrative

The analyses were performed according to the guidelines in the WATERLAB Corp Quality Assurance Program. This report contains analytical results for the sample(s) as received by the laboratory.

WATERLAB Corp certifies that this report is in compliance with the requirements of NELAC. No unusual difficulties were experienced during analysis of this batch except as noted below or qualified with data flags on the reports.

Analyte	Method	Acc*	Results	Qual	MRL	Units	EPA Limit	Analysis	
								Date	Time
Lead Schools/Bldgs	SM3113 B	A	0.0013		0.001	mg/l	0.020	06/29/2017	BEM

ND- No Detection at @ MRL

SM-"Standard Methods for the Examination of Water & Wastewater", 19th ed

EPA- "Methods for Chemical Analysis for Water and Wastes", USEPA

MRL-"Method Reporting Limit"

* Accreditation

A- Waterlab Corporation, ORELAP 100039

The results relate only to the parameters tested or to the sample as received by the laboratory.

This report shall not be reproduced except in full, without the written approval of Waterlab Corporation.

Approved by: 

TEST REPORT

2603 - 12th Street, SE
Salem, OR 97302
Voice: (503) 363-0473
FAX: (503) 363-8900

TO: Community Action Head Start
2475 Center ST NE
Salem, OR 97301

07/06/2017

COMACTHS

PO#: 24962

Collection Information

Date: 06/15/2017
Time: 0720
By: Salinas/Kelley
Lab #: 20170620-065
Location: MG 21

Lab Receipt Information

06/20/2017
1101
RD

Case Narrative

The analyses were performed according to the guidelines in the WATERLAB Corp Quality Assurance Program. This report contains analytical results for the sample(s) as received by the laboratory.

WATERLAB Corp certifies that this report is in compliance with the requirements of NELAC. No unusual difficulties were experienced during analysis of this batch except as noted below or qualified with data flags on the reports.

Analyte	Method	Acc*	Results	Qual	MRL	Units	EPA Limit	Analysis	
								Date Time	Tech
Lead Schools/Bldgs	SM3113 B	A	ND		0.001	mg/l	0.020	06/29/2017	BEM

ND- No Detection at @ MRL

SM-"Standard Methods for the Examination of Water & Wastewater", 19th ed

EPA- "Methods for Chemical Analysis for Water and Wastes", USEPA

MRL-"Method Reporting Limit"

* Accreditation

A- Waterlab Corporation, ORELAP 100039

The results relate only to the parameters tested or to the sample as received by the laboratory.

This report shall not be reproduced except in full, without the written approval of Waterlab Corporation.

Approved by: _____



TEST REPORT

TO: Community Action Head Start
2475 Center ST NE
Salem, OR 97301

07/06/2017

COMACTHS

PO#: 24962

Collection Information

Date: 06/15/2017
Time: 0720
By: Salinas/Kelley
Lab #: 20170620-066
Location: MG 22

Lab Receipt Information

06/20/2017
1101
RD

Case Narrative

The analyses were performed according to the guidelines in the WATERLAB Corp Quality Assurance Program. This report contains analytical results for the sample(s) as received by the laboratory.

WATERLAB Corp certifies that this report is in compliance with the requirements of NELAC. No unusual difficulties were experienced during analysis of this batch except as noted below or qualified with data flags on the reports.

Analyte	Method	Acc*	Results	Qual	MRL	Units	EPA Limit	Analysis	
								Date	Time
Lead Schools/Bldgs	SM3113 B	A	ND		0.001	mg/l	0.020	06/29/2017	BEM

ND- No Detection at @ MRL

SM-"Standard Methods for the Examination of Water & Wastewater", 19th ed

EPA- "Methods for Chemical Analysis for Water and Wastes", USEPA

MRL-"Method Reporting Limit"

* Accreditation

A- Waterlab Corporation, ORELAP 100039

The results relate only to the parameters tested or to the sample as received by the laboratory.

This report shall not be reproduced except in full, without the written approval of Waterlab Corporation.

Approved by: _____



TEST REPORT

2603 - 12th Street, SE
Salem, OR 97302
Voice: (503) 363-0473
FAX: (503) 363-8900

TO: Community Action Head Start
2475 Center ST NE
Salem, OR 97301

07/10/2017

COMACTHS

PO#: 24962

Collection Information

Lab Receipt Information

Date: 06/15/2017
Time: 0720
By: Salinas/Kelley
Lab #: 20170620-067
Location: MG 23

06/20/2017
1101
RD

Case Narrative

The analyses were performed according to the guidelines in the WATERLAB Corp Quality Assurance Program. This report contains analytical results for the sample(s) as received by the laboratory.

WATERLAB Corp certifies that this report is in compliance with the requirements of NELAC. No unusual difficulties were experienced during analysis of this batch except as noted below or qualified with data flags on the reports.

Analyte	Method	Acc*	Results	Qual	MRL	Units	EPA Limit	Analysis	
								Date	Time
Lead Schools/Bldgs	SM3113 B	A	ND		0.001	mg/l	0.020	06/29/2017	BEM

ND- No Detection at @ MRL

SM-"Standard Methods for the Examination of Water & Wastewater", 19th ed

EPA- "Methods for Chemical Analysis for Water and Wastes", USEPA

MRL-"Method Reporting Limit"

* Accreditation

A- Waterlab Corporation, ORELAP 100039

The results relate only to the parameters tested or to the sample as received by the laboratory.

This report shall not be reproduced except in full, without the written approval of Waterlab Corporation.

Approved by: _____



TEST REPORT

2603 - 12th Street, SE
Salem, OR 97302
Voice: (503) 363-0473
FAX: (503) 363-8900

TO: Community Action Head Start
2475 Center ST NE
Salem, OR 97301

07/10/2017

COMACTHS

PO#: 24962

Collection Information

Lab Receipt Information

Date: 06/15/2017
Time: 0725
By: Salinas/Kelley
Lab #: 20170620-068
Location: MG EHS 1-1

06/20/2017
1101
RD

Case Narrative

The analyses were performed according to the guidelines in the WATERLAB Corp Quality Assurance Program. This report contains analytical results for the sample(s) as received by the laboratory.

WATERLAB Corp certifies that this report is in compliance with the requirements of NELAC. No unusual difficulties were experienced during analysis of this batch except as noted below or qualified with data flags on the reports.

Analyte	Method	Acc*	Results	Qual	MRL	Units	EPA Limit	Analysis	
								Date	Time
Lead Schools/Bldgs	SM3113 B	A	ND		0.001	mg/l	0.020	06/29/2017	BEM

ND- No Detection at @ MRL

SM-"Standard Methods for the Examination of Water & Wastewater", 19th ed

EPA- "Methods for Chemical Analysis for Water and Wastes", USEPA

MRL-"Method Reporting Limit"

* Accreditation

A- Waterlab Corporation, ORELAP 100039

The results relate only to the parameters tested or to the sample as received by the laboratory.

This report shall not be reproduced except in full, without the written approval of Waterlab Corporation.

Approved by: 

TEST REPORT

TO: Community Action Head Start
2475 Center ST NE
Salem, OR 97301

07/10/2017

COMACTHS

PO#: 24962

Collection Information

Date: 06/15/2017
Time: 0725
By: Salinas/Kelley
Lab #: 20170620-069
Location: MG EHS 1-2

Lab Receipt Information

06/20/2017
1101
RD

Case Narrative

The analyses were performed according to the guidelines in the WATERLAB Corp Quality Assurance Program. This report contains analytical results for the sample(s) as received by the laboratory.

WATERLAB Corp certifies that this report is in compliance with the requirements of NELAC. No unusual difficulties were experienced during analysis of this batch except as noted below or qualified with data flags on the reports.

Analyte	Method	Acc*	Results	Qual	MRL	Units	EPA Limit	Analysis	
								Date	Time
Lead Schools/Bldgs	SM3113 B	A	ND		0.001	mg/l	0.020	06/29/2017	BEM

ND- No Detection at @ MRL

SM-"Standard Methods for the Examination of Water & Wastewater", 19th ed

EPA- "Methods for Chemical Analysis for Water and Wastes", USEPA

MRL-"Method Reporting Limit"

* Accreditation

A- Waterlab Corporation, ORELAP 100039

The results relate only to the parameters tested or to the sample as received by the laboratory.

This report shall not be reproduced except in full, without the written approval of Waterlab Corporation.

Approved by: 

TEST REPORT

2603 - 12th Street, SE
Salem, OR 97302
Voice: (503) 363-0473
FAX: (503) 363-8900

TO: Community Action Head Start
2475 Center ST NE
Salem, OR 97301

07/10/2017

COMACTHS

PO#: 24962

Collection Information

Date: 06/15/2017
Time: 0725
By: Salinas/Kelley
Lab #: 20170620-070
Location: MG EHS 1-3

Lab Receipt Information

06/20/2017
1101
RD

Case Narrative

The analyses were performed according to the guidelines in the WATERLAB Corp Quality Assurance Program. This report contains analytical results for the sample(s) as received by the laboratory.

WATERLAB Corp certifies that this report is in compliance with the requirements of NELAC. No unusual difficulties were experienced during analysis of this batch except as noted below or qualified with data flags on the reports.

Analyte	Method	Acc*	Results	Qual	MRL	Units	EPA Limit	Analysis	
								Date Time	Tech
Lead Schools/Bldgs	SM3113 B	A	0.0012		0.001	mg/l	0.020	06/29/2017	BEM

ND- No Detection at @ MRL

SM-"Standard Methods for the Examination of Water & Wastewater", 19th ed

EPA- "Methods for Chemical Analysis for Water and Wastes", USEPA

MRL-"Method Reporting Limit"

* Accreditation

A- Waterlab Corporation, ORELAP 100039

The results relate only to the parameters tested or to the sample as received by the laboratory.

This report shall not be reproduced except in full, without the written approval of Waterlab Corporation.

Approved by: _____



TEST REPORT

TO: Community Action Head Start
2475 Center ST NE
Salem, OR 97301

07/10/2017

COMACTHS

PO#: 24962

Collection Information

Lab Receipt Information

Date: 06/15/2017
Time: 0730
By: Salinas/Kelley
Lab #: 20170620-071
Location: MG EHS 2-1

06/20/2017
1101
RD

Case Narrative

The analyses were performed according to the guidelines in the WATERLAB Corp Quality Assurance Program. This report contains analytical results for the sample(s) as received by the laboratory.

WATERLAB Corp certifies that this report is in compliance with the requirements of NELAC. No unusual difficulties were experienced during analysis of this batch except as noted below or qualified with data flags on the reports.

Analyte	Method	Acc*	Results	Qual	MRL	Units	EPA Limit	Analysis	
								Date Time	Tech
Lead Schools/Bldgs	SM3113 B	A	ND		0.001	mg/l	0.020	06/29/2017	BEM

ND- No Detection at @ MRL

SM-"Standard Methods for the Examination of Water & Wastewater", 19th ed

EPA- "Methods for Chemical Analysis for Water and Wastes", USEPA

MRL-"Method Reporting Limit"

* Accreditation

A- Waterlab Corporation, ORELAP 100039

The results relate only to the parameters tested or to the sample as received by the laboratory.

This report shall not be reproduced except in full, without the written approval of Waterlab Corporation.

Approved by: _____



TEST REPORT

2603 - 12th Street, SE
Salem, OR 97302
Voice: (503) 363-0473
FAX: (503) 363-8900

TO: Community Action Head Start
2475 Center ST NE
Salem, OR 97301

07/10/2017

COMACTHS

PO#: 24962

Collection Information

Date: 06/15/2017
Time: 0730
By: Salinas/Kelley
Lab #: 20170620-072
Location: MG EHS 2-2

Lab Receipt Information

06/20/2017
1101
RD

Case Narrative

The analyses were performed according to the guidelines in the WATERLAB Corp Quality Assurance Program. This report contains analytical results for the sample(s) as received by the laboratory.

WATERLAB Corp certifies that this report is in compliance with the requirements of NELAC. No unusual difficulties were experienced during analysis of this batch except as noted below or qualified with data flags on the reports.

Analyte	Method	Acc*	Results	Qual	MRL	Units	EPA Limit	Analysis	
								Date	Time
Lead	Schools/Bldgs	SM3113 B	A	ND	0.001	mg/l	0.020	06/29/2017	BEM

ND- No Detection at @ MRL

SM-"Standard Methods for the Examination of Water & Wastewater", 19th ed

EPA- "Methods for Chemical Analysis for Water and Wastes", USEPA

MRL-"Method Reporting Limit"

* Accreditation

A- Waterlab Corporation, ORELAP 100039

The results relate only to the parameters tested or to the sample as received by the laboratory.

This report shall not be reproduced except in full, without the written approval of Waterlab Corporation.

Approved by: _____

TEST REPORT

TO: Community Action Head Start
2475 Center ST NE
Salem, OR 97301

07/10/2017

COMACTHS

PO#: 24962

Collection Information

Date: 06/15/2017
Time: 0730
By: Salinas/Kelley
Lab #: 20170620-073
Location: MG EHS 2-3

Lab Receipt Information

06/20/2017
1101
RD

Case Narrative

The analyses were performed according to the guidelines in the WATERLAB Corp Quality Assurance Program. This report contains analytical results for the sample(s) as received by the laboratory.

WATERLAB Corp certifies that this report is in compliance with the requirements of NELAC. No unusual difficulties were experienced during analysis of this batch except as noted below or qualified with data flags on the reports.

Analyte	Method	Acc*	Results	Qual	MRL	Units	EPA Limit	Analysis	
								Date Time	Tech
Lead Schools/Bldgs	SM3113 B	A	ND		0.001	mg/l	0.020	06/29/2017	BEM

ND- No Detection at @ MRL

SM-"Standard Methods for the Examination of Water & Wastewater", 19th ed

EPA- "Methods for Chemical Analysis for Water and Wastes", USEPA

MRL-"Method Reporting Limit"

* Accreditation

A- Waterlab Corporation, ORELAP 100039

The results relate only to the parameters tested or to the sample as received by the laboratory.

This report shall not be reproduced except in full, without the written approval of Waterlab Corporation.

Approved by: 

TEST REPORT

2603 - 12th Street, SE
Salem, OR 97302
Voice: (503) 363-0473
FAX: (503) 363-8900

TO: Community Action Head Start
2475 Center ST NE
Salem, OR 97301

09/21/2017

COMACTHS

PO#: 24962

Collection Information

Date: 09/08/2017

Time: 0707

By: Ron

Lab #: 20170908-002

Location: Middle Grove classroom 4 second draw

Lab Receipt Information

09/08/2017

0842

MH

Case Narrative

The analyses were performed according to the guidelines in the WATERLAB Corp Quality Assurance Program. This report contains analytical results for the sample(s) as received by the laboratory.

WATERLAB Corp certifies that this report is in compliance with the requirements of NELAC. No unusual difficulties were experienced during analysis of this batch except as noted below or qualified with data flags on the reports.

Analyte	Method	Acc*	Results	Qual	MRL	Units	EPA Limit	Analysis	
								Date	Time
Lead Schools/Bldgs	SM3113 B	A	ND		0.001	mg/l	0.020	09/12/2017	BEM

ND- No Detection at @ MRL

SM-"Standard Methods for the Examination of Water & Wastewater";19th ed

EPA- "Methods for Chemical Analysis for Water and Wastes", USEPA

MRL-"Method Reporting Limit"

* Accreditation

A- Waterlab Corporation, ORELAP 100039

The results relate only to the parameters tested or to the sample as received by the laboratory.

This report shall not be reproduced except in full, without the written approval of Waterlab Corporation.

Approved by: 