WATERLAB CORP. 2603 12th Street SE

Salem, OR 97302

z z z 05232022 09:55 Date/Time: Correct Container Correct Volume

Hold Time

Rec'd By: 1

Relinquished

Signature

Printed Name

SEND RESULTS TO:

Address: - 2475 Cewter StAR City: Salor

Phone: 503-508-8206 Zip Code: _

SEND BILL TO:

Address: City:

Name:

State; Phone:

Zip Code:

PROJECT:

127/ by the Lead

COLLECTED BY:

P P

05/23

600 Am

625

Pb, 25/23/22 1:00 pm SOURCE **JATE** AB# IIME **TEST**

dd ascade KH 600 Am 85/23 2022024 11tche 2 P q d 22/53/50 Cascacle 8-00 Am 20220523-023 P Sed 05/23/22 600 Am 13-022 rascade children

| EST | Pb | h Pb | Plo | Pb | pb.dq |
|-------|--------------------|--|------|----|-----------|
| ATE | 05/23/22 | | | | diameter) |
| IME | 600 fm | The state of the s | 7450 | | |
| OURCE | Cascade Class Room | | | | |
| AB# | 10220513-027 | | | | |

F37



2603 - 12th Street, SE Salem, OR 97302 Voice: (503) 363-0473 FAX: (503) 363-8900

TO: Community Action Headstart / Ken Hamlin

2475 Center St NE Salem, OR 97301 6/13/2022

COMACTHS

PO#:

Collection Information

Date: 5/23/2022 Time: 0600

By: Greg Ellison

Lab #: 20220523-022

Location: Cascade ChildRR Left

Lab Receipt Information

5/23/2022 0955 SW

Case Narrative

The analyses were performed according to the guidelines in the WATERLAB Corp Quality Assurance Program. This report contains analytical results for the sample(s) as received by the laboratory.

WATERLAB Corp certifies that this report is in compliance with the requirements of NELAP. No unusual difficulties were experienced during analysis of this batch except as noted below or qualified with data flags on the reports.

| The state of the s | | | | | | | EPA | Analys | is |
|--|----------|-----|-----------|------|-----|-------|-------|-----------|------|
| Analyte | Method | Acc | * Results | Qual | MRL | Units | Limit | Date Time | Tech |
| Lead / Schools | SM3113 B | Α | ND | | 1 | ppb | 15 | 6/6/2022 | BEM |

ND- No Detection at @ MRL SM-"Standard Methods for the Examination of Water & Wastewater",19th ed EPA- "Methods for Chemical Analysis for Water and Wastes",USEPA MRL-"Method Reporting Limit" * Accreditation A- Waterlab Corporation, ORELAP 100039

The results relate only to the parameters tested or to the sample as received by the laboratory.

This report shall not be reproduced except in full, without the written approval of Waterlab Corporation.

| | k |
|--------------|---|
| Approved by: | |



2603 - 12th Street, SE Salem, OR 97302 Voice: (503) 363-0473 FAX: (503) 363-8900

TO: Community Action Headstart / Ken Hamlin

2475 Center St NE Salem, OR 97301 6/13/2022

COMACTHS

PO#:

Collection Information

Date: 5/23/2022 Time: 0600

By: Greg Ellison

Lab #: 20220523-023

Location: Cascade ChilRR Right

Lab Receipt Information

5/23/2022 0955 SW

Case Narrative

The analyses were performed according to the guidelines in the WATERLAB Corp Quality Assurance Program. This report contains analytical results for the sample(s) as received by the laboratory.

WATERLAB Corp certifies that this report is in compliance with the requirements of NELAP. No unusual difficulties were experienced during analysis of this batch except as noted below or qualified with data flags on the reports.

| | | | | | | | EPA | Analys | is |
|----------------|----------|------|---------|------|-----|-------|-------|-----------|------|
| Analyte | Method | Acc* | Results | Qual | MRL | Units | Limit | Date Time | Tech |
| Lead / Schools | SM3113 B | Α | ND | | 1 | ppb | 15 | 6/6/2022 | BEM |

ND- No Detection at @ MRL SM-"Standard Methods for the Examination of Water & Wastewater",19th ed EPA- "Methods for Chemical Analysis for Water and Wastes",USEPA MRL-"Method Reporting Limit" * Accreditation A- Waterlab Corporation, ORELAP 100039

The results relate only to the parameters tested or to the sample as received by the laboratory.

This report shall not be reproduced except in full, without the written approval of Waterlab Corporation.

Approved by: _____



2603 - 12th Street, SE Salem, OR 97302 Voice: (503) 363-0473 FAX: (503) 363-8900

TO: Community Action Headstart / Ken Hamlin

2475 Center St NE Salem, OR 97301 6/13/2022

COMACTHS

PO#:

Collection Information

Date: 5/23/2022 Time: 0600

By: Greg Ellison

Lab #: 20220523-024

Location: Cascade Kit HW Sink

Lab Receipt Information

5/23/2022 0955 SW

Case Narrative

The analyses were performed according to the guidelines in the WATERLAB Corp Quality Assurance Program. This report contains analytical results for the sample(s) as received by the laboratory.

WATERLAB Corp certifies that this report is in compliance with the requirements of NELAP. No unusual difficulties were experienced during analysis of this batch except as noted below or qualified with data flags on the reports.

| | | | | | | mir. | EPA | Analys | is |
|----------------|----------|-----|-----------|------|-----|-------|-------|-----------|------|
| Analyte | Method | Acc | * Results | Qual | MRL | Units | Limit | Date Time | Tech |
| Lead / Schools | SM3113 B | Α | 12.6 | | 1 | ppb | 15 | 6/6/2022 | BEM |

ND- No Detection at @ MRL SM-"Standard Methods for the Examination of Water & Wastewater",19th ed EPA- "Methods for Chemical Analysis for Water and Wastes",USEPA MRL-"Method Reporting Limit" * Accreditation

A- Waterlab Corporation, ORELAP 100039

The results relate only to the parameters tested or to the sample as received by the laboratory.

This report shall not be reproduced except in full, without the written approval of Waterlab Corporation.

| | jω |
|--------------|----|
| Approved by: | |



2603 - 12th Street, SE Salem, OR 97302 Voice: (503) 363-0473 FAX: (503) 363-8900

TO: Community Action Headstart / Ken Hamlin

2475 Center St NE Salem, OR 97301 6/13/2022

COMACTHS

PO#:

Collection Information

Date: 5/23/2022 Time: 0600

By: Greg Ellison

Lab #: Location:

the laboratory.

20220523-025

Cascade Kit DW Sink

Lab Receipt Information

5/23/2022 0955 SW

Case Narrative

The analyses were performed according to the guidelines in the WATERLAB Corp Quality Assurance Program. This report contains analytical results for the sample(s) as received by the laboratory.

WATERLAB Corp certifies that this report is in compliance with the requirements of NELAP. No unusual difficulties were experienced during analysis of this batch except as noted below or qualified with data flags on the reports.

| | 2000000 | | | | | | EPA | Analys | is |
|----------------|----------|-----|---------|------|-----|-------|-------|-----------|------|
| Analyte | Method | Acc | Results | Qual | MRL | Units | Limit | Date Time | Tech |
| Lead / Schools | SM3113 B | Α | 4.03 | | 1 | ppb | 15 | 6/6/2022 | BEM |

ND- No Detection at @ MRL
SM-"Standard Methods for the Examination of Water & Wastewater",19th ed
EPA- "Methods for Chemical Analysis for Water and Wastes",USEPA
MRL-"Method Reporting Limit"
* Accreditation
A- Waterlab Corporation, ORELAP 100039
The results relate only to the parameters tested or to the sample as received by

This report shall not be reproduced except in full, without the written approval of Waterlab Corporation.

| | \mathcal{W} |
|--------------|---|
| Approved by: | j , , , , , , , , , , , , , , , , , , , |

1



2603 - 12th Street, SE Salem, OR 97302 Voice: (503) 363-0473 FAX: (503) 363-8900

TO: Community Action Headstart / Ken Hamlin

2475 Center St NE Salem, OR 97301

6/13/2022

Lab Receipt Information

5/23/2022

0955

SW

COMACTHS

PO#:

Collection Information

Date: 5/23/2022 Time: 0600

Greg Ellison Bv:

Lab #: Location: 20220523-026 Cascade Kit FP Sink

Case Narrative

The analyses were performed according to the guidelines in the WATERLAB Corp Quality Assurance Program. This report contains analytical results for the sample(s) as received by the laboratory.

WATERLAB Corp certifies that this report is in compliance with the requirements of NELAP. No unusual difficulties were experienced during analysis of this batch except as noted below or qualified with data flags on the reports.

| | | • | | | | | EPA | Analys | is |
|----------------|----------|------|---------|------|-----|-------|-------|-----------|------|
| Analyte | Method | Acc* | Results | Qual | MRL | Units | Limit | Date Time | Tech |
| Lead / Schools | SM3113 B | Α | 6.99 | | 1 | ppb | 15 | 6/6/2022 | BEM |

ND- No Detection at @ MRL SM-"Standard Methods for the Examination of Water & Wastewater", 19th ed EPA- "Methods for Chemical Analysis for Water and Wastes", USEPA MRL-"Method Reporting Limit"

* Accreditation

A- Waterlab Corporation, ORELAP 100039

The results relate only to the parameters tested or to the sample as received by the laboratory.

This report shall not be reproduced except in full, without the written approval of Waterlab Corporation.

Approved by: _



2603 - 12th Street, SE Salem, OR 97302 Voice: (503) 363-0473 FAX: (503) 363-8900

TO: Community Action Headstart / Ken Hamlin

6/13/2022

2475 Center St NE Salem, OR 97301

COMACTHS

PO#:

Collection Information

Lab Receipt Information

Date: 5/23/2022 Time: 0600

5/23/2022 0955

SW

Greg Ellison By:

20220523-027

Location:

Cascade CR Tub Sink

Case Narrative

Lab #:

The analyses were performed according to the guidelines in the WATERLAB Corp Quality Assurance Program. This report contains analytical results for the sample(s) as received by the laboratory.

WATERLAB Corp certifies that this report is in compliance with the requirements of NELAP. No unusual difficulties were experienced during analysis of this batch except as noted below or qualified with data flags on the reports.

| | | | | | | | EPA | Analys | is |
|----------------|----------|-----|-----------|------|-----|-------|-------|-----------|------|
| Analyte | Method | Acc | * Results | Qual | MRL | Units | Limit | Date Time | Tech |
| Lead / Schools | SM3113 B | Α | 2.81 | | 1 | ppb | 15 | 6/6/2022 | BEM |

ND- No Detection at @ MRL SM-"Standard Methods for the Examination of Water & Wastewater",19th ed EPA- "Methods for Chemical Analysis for Water and Wastes", USEPA MRL-"Method Reporting Limit" * Accreditation A- Waterlab Corporation, ORELAP 100039 The results relate only to the parameters tested or to the sample as received by the laboratory.

This report shall not be reproduced except in full, without the written approval of Waterlab Corporation.

| | K |
|--------------|---|
| Approved by: | 1 |

/,