

WATERLAB CORP.

2603 12th Street SE
Salem, OR 97302

Date/Time: 05232022 09:55

Relinquished

Correct Container / N
Correct Volume / N
Hold Time / N

Rec'd By: [Signature]

By: _____ Signature
Printed Name

SEND RESULTS TO:

Co. Name: CAHS
Address: 2475 Center St. NE
City: Salem State: OR
Zip Code: 97301 Phone: 503 508 8206

SEND BILL TO:

Name: _____
Address: _____
City: _____ State: _____
Zip Code: _____ Phone: _____

PROJECT: Lead

27 / bottle

COLLECTED BY: C. Vegelson

TEST	DATE	TIME	SOURCE	AB #	Pb
	05/21/22	1:15 pm	Judy kitchen double dish sink	20220523-114	Pb
	05/21/22	1:15 pm	Judy kitchen single hand wash sink	20220523-115	Pb
	05/21/22	1:15 pm	Judy office restroom	20220523-116	Pb
	05/21/22	1:25 pm	Judy single adult handwash	20220523-117	Pb
	05/21/22	1:25 pm	Judy pre-K double adult handwash	20220523-118	Pb

TEST	DATE	TIME	SOURCE	AB #	Pb
	05/21/22	1:25 pm	Judy pre-K left childrens handwash	20220523-119	Pb
	05/21/22	1:25 pm	Judy pre-K right childrens handwash	20220523-120	Pb
	05/21/22	1:45 pm	Judy childrens handwash	20220523-121	Pb

Independence (Judy)

TEST REPORT

2603 - 12th Street, SE
Salem, OR 97302
Voice: (503) 363-0473
FAX: (503) 363-8900

TO: Community Action Headstart / Ken Hamlin
2475 Center St NE
Salem, OR 97301

6/13/2022

COMACTHS

PO#:

Collection Information

Date: 5/21/2022
Time: 1315
By: Greg Ellison
Lab #: 20220523-114
Location: Indy Kit DB DishSink

Lab Receipt Information

5/23/2022
0955
SW

Case Narrative

The analyses were performed according to the guidelines in the WATERLAB Corp Quality Assurance Program. This report contains analytical results for the sample(s) as received by the laboratory.

WATERLAB Corp certifies that this report is in compliance with the requirements of NELAP. No unusual difficulties were experienced during analysis of this batch except as noted below or qualified with data flags on the reports.

Analyte	Method	Acc*	Results	Qual	MRL	Units	EPA Limit	Analysis	
								Date	Time
Lead / Schools	SM3113 B	A	ND		1	ppb	15	6/6/2022	bem

ND- No Detection at @ MRL

SM-"Standard Methods for the Examination of Water & Wastewater", 19th ed

EPA- "Methods for Chemical Analysis for Water and Wastes", USEPA

MRL-"Method Reporting Limit"

* Accreditation

A- Waterlab Corporation, ORELAP 100039

The results relate only to the parameters tested or to the sample as received by the laboratory.

This report shall not be reproduced except in full, without the written approval of Waterlab Corporation.

Approved by: _____



TEST REPORT

TO: Community Action Headstart / Ken Hamlin
2475 Center St NE
Salem, OR 97301

6/13/2022

COMACTHS

PO#:

Collection Information

Date: 5/21/2022
Time: 1315
By: Greg Ellison
Lab #: 20220523-115
Location: Indy Kit Sing HWSink

Lab Receipt Information

5/23/2022
0955
SW

Case Narrative

The analyses were performed according to the guidelines in the WATERLAB Corp Quality Assurance Program. This report contains analytical results for the sample(s) as received by the laboratory.

WATERLAB Corp certifies that this report is in compliance with the requirements of NELAP. No unusual difficulties were experienced during analysis of this batch except as noted below or qualified with data flags on the reports.

Analyte	Method	Acc*	Results	Qual	MRL	Units	EPA Limit	Analysis	
								Date	Time
Lead / Schools	SM3113 B	A	12.6		1	ppb	15	6/10/2022	bern

ND- No Detection at @ MRL

SM-"Standard Methods for the Examination of Water & Wastewater", 19th ed

EPA- "Methods for Chemical Analysis for Water and Wastes", USEPA

MRL-"Method Reporting Limit"

* Accreditation

A- Waterlab Corporation, ORELAP 100039

The results relate only to the parameters tested or to the sample as received by the laboratory.

This report shall not be reproduced except in full, without the written approval of Waterlab Corporation.

Approved by: _____



TEST REPORT

2603 - 12th Street, SE
Salem, OR 97302
Voice: (503) 363-0473
FAX: (503) 363-8900

TO: Community Action Headstart / Ken Hamlin
2475 Center St NE
Salem, OR 97301

6/13/2022

COMACTHS

PO#:

Collection Information

Date: 5/21/2022
Time: 1315
By: Greg Ellison
Lab #: 20220523-116
Location: Indy Office Restroom

Lab Receipt Information

5/23/2022
0955
SW

Case Narrative

The analyses were performed according to the guidelines in the WATERLAB Corp Quality Assurance Program. This report contains analytical results for the sample(s) as received by the laboratory.

WATERLAB Corp certifies that this report is in compliance with the requirements of NELAP. No unusual difficulties were experienced during analysis of this batch except as noted below or qualified with data flags on the reports.

Analyte	Method	Acc*	Results	Qual	MRL	Units	EPA Limit	Analysis	
								Date	Time
Lead / Schools	SM3113 B	A	9.43		1	ppb	15	6/10/2022	bern

ND- No Detection at @ MRL

SM-"Standard Methods for the Examination of Water & Wastewater", 19th ed

EPA- "Methods for Chemical Analysis for Water and Wastes", USEPA

MRL-"Method Reporting Limit"

* Accreditation

A- Waterlab Corporation, ORELAP 100039

The results relate only to the parameters tested or to the sample as received by the laboratory.

This report shall not be reproduced except in full, without the written approval of Waterlab Corporation.

Approved by: _____



TEST REPORT

TO: Community Action Headstart / Ken Hamlin
2475 Center St NE
Salem, OR 97301

6/13/2022

COMACTHS

PO#:

Collection Information

Date: 5/21/2022
Time: 1325
By: Greg Ellison
Lab #: 20220523-117
Location: Indy Sing Adult HW

Lab Receipt Information

5/23/2022
0955
SW

Case Narrative

The analyses were performed according to the guidelines in the WATERLAB Corp Quality Assurance Program. This report contains analytical results for the sample(s) as received by the laboratory.

WATERLAB Corp certifies that this report is in compliance with the requirements of NELAP. No unusual difficulties were experienced during analysis of this batch except as noted below or qualified with data flags on the reports.

Analyte	Method	Acc*	Results	Qual	MRL	Units	EPA Limit	Analysis	
								Date Time	Tech
Lead / Schools	SM3113 B	A	ND		1	ppb	15	6/10/2022	bem

ND- No Detection at @ MRL

SM-"Standard Methods for the Examination of Water & Wastewater", 19th ed

EPA- "Methods for Chemical Analysis for Water and Wastes", USEPA

MRL-"Method Reporting Limit"

* Accreditation

A- Waterlab Corporation, ORELAP 100039

The results relate only to the parameters tested or to the sample as received by the laboratory.

This report shall not be reproduced except in full, without the written approval of Waterlab Corporation.

Approved by: _____



TEST REPORT

TO: Community Action Headstart / Ken Hamlin
2475 Center St NE
Salem, OR 97301

6/13/2022

COMACTHS

PO#:

Collection Information

Date: 5/21/2022
Time: 1325
By: Greg Ellison
Lab #: 20220523-118
Location: Indy PreK DB AdultHW

Lab Receipt Information

5/23/2022
0955
SW

Case Narrative

The analyses were performed according to the guidelines in the WATERLAB Corp Quality Assurance Program. This report contains analytical results for the sample(s) as received by the laboratory.

WATERLAB Corp certifies that this report is in compliance with the requirements of NELAP. No unusual difficulties were experienced during analysis of this batch except as noted below or qualified with data flags on the reports.

Analyte	Method	Acc*	Results	Qual	MRL	Units	EPA Limit	Analysis	
								Date	Time
Lead / Schools	SM3113 B	A	ND		1	ppb	15	6/10/2022	bem

ND- No Detection at @ MRL

SM-"Standard Methods for the Examination of Water & Wastewater", 19th ed

EPA- "Methods for Chemical Analysis for Water and Wastes", USEPA

MRL-"Method Reporting Limit"

* Accreditation

A- Waterlab Corporation, ORELAP 100039

The results relate only to the parameters tested or to the sample as received by the laboratory.

This report shall not be reproduced except in full, without the written approval of Waterlab Corporation.

Approved by: _____



TEST REPORT

TO: Community Action Headstart / Ken Hamlin
2475 Center St NE
Salem, OR 97301

6/13/2022

COMACTHS

PO#:

Collection Information

Date: 5/21/2022
Time: 1325
By: Greg Ellison
Lab #: 20220523-119
Location: Indy PreK L Child HW

Lab Receipt Information

5/23/2022
0955
SW

Case Narrative

The analyses were performed according to the guidelines in the WATERLAB Corp Quality Assurance Program. This report contains analytical results for the sample(s) as received by the laboratory.

WATERLAB Corp certifies that this report is in compliance with the requirements of NELAP. No unusual difficulties were experienced during analysis of this batch except as noted below or qualified with data flags on the reports.

Analyte	Method	Acc*	Results	Qual	MRL	Units	EPA Limit	Analysis	
								Date	Time
Lead / Schools	SM3113 B	A	ND		1	ppb	15	6/10/2022	bem

ND- No Detection at @ MRL

SM-"Standard Methods for the Examination of Water & Wastewater", 19th ed

EPA- "Methods for Chemical Analysis for Water and Wastes", USEPA

MRL-"Method Reporting Limit"

* Accreditation

A- Waterlab Corporation, ORELAP 100039

The results relate only to the parameters tested or to the sample as received by the laboratory.

This report shall not be reproduced except in full, without the written approval of Waterlab Corporation.

Approved by: _____



TEST REPORT

2603 - 12th Street, SE
Salem, OR 97302
Voice: (503) 363-0473
FAX: (503) 363-8900

TO: Community Action Headstart / Ken Hamlin
2475 Center St NE
Salem, OR 97301

6/13/2022

COMACTHS

PO#:

Collection Information

Date: 5/21/2022
Time: 1325
By: Greg Ellison
Lab #: 20220523-120
Location: Indy PreK R Child HW

Lab Receipt Information

5/23/2022
0955
SW

Case Narrative

The analyses were performed according to the guidelines in the WATERLAB Corp Quality Assurance Program. This report contains analytical results for the sample(s) as received by the laboratory.

WATERLAB Corp certifies that this report is in compliance with the requirements of NELAP. No unusual difficulties were experienced during analysis of this batch except as noted below or qualified with data flags on the reports.

Analyte	Method	Acc*	Results	Qual	MRL	Units	EPA Limit	Analysis	
								Date	Time
Lead / Schools	SM3113 B	A	ND		1	ppb	15	6/6/2022	bem

ND- No Detection at @ MRL

SM-"Standard Methods for the Examination of Water & Wastewater", 19th ed

EPA- "Methods for Chemical Analysis for Water and Wastes", USEPA

MRL-"Method Reporting Limit"

* Accreditation

A- Waterlab Corporation, ORELAP 100039

The results relate only to the parameters tested or to the sample as received by the laboratory.

This report shall not be reproduced except in full, without the written approval of Waterlab Corporation.

Approved by: _____



TEST REPORT

TO: Community Action Headstart / Ken Hamlin
2475 Center St NE
Salem, OR 97301

6/13/2022

COMACTHS

PO#:

Collection Information

Date: 5/21/2022
Time: 1345
By: Greg Ellison
Lab #: 20220523-121
Location: Indy L Child HW

Lab Receipt Information

5/23/2022
0955
SW

Case Narrative

The analyses were performed according to the guidelines in the WATERLAB Corp Quality Assurance Program. This report contains analytical results for the sample(s) as received by the laboratory.

WATERLAB Corp certifies that this report is in compliance with the requirements of NELAP. No unusual difficulties were experienced during analysis of this batch except as noted below or qualified with data flags on the reports.

Analyte	Method	Acc*	Results	Qual	MRL	Units	EPA Limit	Analysis	
								Date	Time
Lead / Schools	SM3113 B	A	1.46		1	ppb	15	6/6/2022	bern

ND- No Detection at @ MRL

SM-"Standard Methods for the Examination of Water & Wastewater", 19th ed

EPA- "Methods for Chemical Analysis for Water and Wastes", USEPA

MRL-"Method Reporting Limit"

* Accreditation

A- Waterlab Corporation, ORELAP 100039

The results relate only to the parameters tested or to the sample as received by the laboratory.

This report shall not be reproduced except in full, without the written approval of Waterlab Corporation.

Approved by: _____



TEST REPORT

2603 - 12th Street, SE
Salem, OR 97302
Voice: (503) 363-0473
FAX: (503) 363-8900

TO: Community Action Headstart / Ken Hamlin
2475 Center St NE
Salem, OR 97301

6/10/2022

COMACTHS

PO#:

Collection Information

Date: 5/21/2022
Time: 1345
By: Greg Ellison
Lab #: 20220523-122
Location: Indy R Child HW

Lab Receipt Information

5/23/2022
0955
SW

Case Narrative

The analyses were performed according to the guidelines in the WATERLAB Corp Quality Assurance Program. This report contains analytical results for the sample(s) as received by the laboratory.

WATERLAB Corp certifies that this report is in compliance with the requirements of NELAP. No unusual difficulties were experienced during analysis of this batch except as noted below or qualified with data flags on the reports.

Analyte	Method	Acc*	Results	Qual	MRL	Units	Analysis	
							Date Time	Tech
Lead / Schools	SM3113 B	A	2.01		1	ppb	6/10/2022	bem

ND- No Detection at @ MRL

SM-"Standard Methods for the Examination of Water & Wastewater", 19th ed

EPA- "Methods for Chemical Analysis for Water and Wastes", USEPA

MRL-"Method Reporting Limit"

* Accreditation

A- Waterlab Corporation, ORELAP 100039

The results relate only to the parameters tested or to the sample as received by the laboratory.

This report shall not be reproduced except in full, without the written approval of Waterlab Corporation.

Approved by: _____