

# WATERLAB CORP.

2603 12<sup>th</sup> Street SE  
Salem, OR 97302

05232022 09:55

Date/Time:

Correct Container Y / N

Correct Volume Y / N

Hold Time Y / N

Rec'd By:

Signature

By:

Relinquished

Printed Name

*Lan Casire*

### SEND RESULTS TO:

Co. Name: CARHS - Ken Hamlin

Address: 2475 CENTER ST NE

City: SALEM State: OREGON

Zip Code: 97301 Phone: 503.508.8106

### SEND BILL TO:

Name: \_\_\_\_\_

Address: \_\_\_\_\_

City: \_\_\_\_\_ State: \_\_\_\_\_

Zip Code: \_\_\_\_\_ Phone: \_\_\_\_\_

PROJECT:

Lead [redacted] #27/ bottles 12

COLLECTED BY: James Pilcher

9 10 11

TEST	Pb, [redacted]	Pb, [redacted]	Pb, [redacted]	Pb, [redacted]	Pb, [redacted]
DATE	5/23/22	5/23/22	5/23/22	5/23/22	5/23/22
TIME	7:01	6:59	7:05	7:15	7:10
SOURCE	Lancaster Kitch HANDSINK	Lancaster Kitch Dish Wash	Lancaster CR3 Main Area	Lancaster CR3 Adult SINK	Lancaster CR3 TOILET SINK LEFT
AB #	20220523-137	20220523-138	20220523-139	20220523-140	20220523-141

*12*

TEST	Pb, [redacted]	Pb, [redacted]	Pb, [redacted]	Pb, [redacted]	Pb, [redacted]
DATE	5/23/22				
TIME	7:11				
SOURCE	Lancaster CR3 TOILET SINK Right				
AB #	20220523-142				

## TEST REPORT

2603 - 12th Street, SE  
Salem, OR 97302  
Voice: (503) 363-0473  
FAX: (503) 363-8900

TO: Community Action Headstart / Ken Hamlin  
2475 Center St NE  
Salem, OR 97301

6/13/2022

COMACTHS

PO#:

### Collection Information

Date: 5/21/2022  
Time: 0701  
By: James Pilcher  
Lab #: 20220523-137  
Location: Lncstr Kit Handsink

### Lab Receipt Information

5/23/2022  
0955  
SW

### Case Narrative

The analyses were performed according to the guidelines in the WATERLAB Corp Quality Assurance Program. This report contains analytical results for the sample(s) as received by the laboratory.

WATERLAB Corp certifies that this report is in compliance with the requirements of NELAP. No unusual difficulties were experienced during analysis of this batch except as noted below or qualified with data flags on the reports.

Analyte	Method	Acc*	Results	Qual	MRL	Units	EPA Limit	Analysis	
								Date	Time
Lead / Schools	SM3113 B	A	ND		1	ppb	15	6/10/2022	bem

ND- No Detection at @ MRL

SM-"Standard Methods for the Examination of Water & Wastewater", 19th ed

EPA- "Methods for Chemical Analysis for Water and Wastes", USEPA

MRL-"Method Reporting Limit"

\* Accreditation

A- Waterlab Corporation, ORELAP 100039

The results relate only to the parameters tested or to the sample as received by the laboratory.

This report shall not be reproduced except in full, without the written approval of Waterlab Corporation.

Approved by: \_\_\_\_\_



## TEST REPORT

TO: Community Action Headstart / Ken Hamlin  
2475 Center St NE  
Salem, OR 97301

6/13/2022

COMACTHS

PO#:

### Collection Information

Date: 5/21/2022  
Time: 0659  
By: James Pilcher  
Lab #: 20220523-138  
Location: Lncstr Kit Dishwash

### Lab Receipt Information

5/23/2022  
0955  
SW

### Case Narrative

The analyses were performed according to the guidelines in the WATERLAB Corp Quality Assurance Program. This report contains analytical results for the sample(s) as received by the laboratory.

WATERLAB Corp certifies that this report is in compliance with the requirements of NELAP. No unusual difficulties were experienced during analysis of this batch except as noted below or qualified with data flags on the reports.

Analyte	Method	Acc*	Results	Qual	MRL	Units	EPA Limit	Analysis	
								Date	Time
Lead / Schools	SM3113 B	A	ND		1	ppb	15	6/10/2022	bern

ND- No Detection at @ MRL

SM-"Standard Methods for the Examination of Water & Wastewater", 19th ed

EPA- "Methods for Chemical Analysis for Water and Wastes", USEPA

MRL-"Method Reporting Limit"

\* Accreditation

A- Waterlab Corporation, ORELAP 100039

The results relate only to the parameters tested or to the sample as received by the laboratory.

This report shall not be reproduced except in full, without the written approval of Waterlab Corporation.

Approved by: \_\_\_\_\_



## TEST REPORT

TO: Community Action Headstart / Ken Hamlin  
2475 Center St NE  
Salem, OR 97301

6/13/2022

COMACTHS

PO#:

### Collection Information

Date: 5/21/2022  
Time: 0705  
By: James Pilcher  
Lab #: 20220523-139  
Location: Lncstr CR3 Main Area

### Lab Receipt Information

5/23/2022  
0955  
SW

### Case Narrative

The analyses were performed according to the guidelines in the WATERLAB Corp Quality Assurance Program. This report contains analytical results for the sample(s) as received by the laboratory.

WATERLAB Corp certifies that this report is in compliance with the requirements of NELAP. No unusual difficulties were experienced during analysis of this batch except as noted below or qualified with data flags on the reports.

Analyte	Method	Acc*	Results	Qual	MRL	Units	EPA Limit	Analysis	
								Date	Time
Lead / Schools	SM3113 B	A	ND		1	ppb	15	6/10/2022	bem

ND- No Detection at @ MRL

SM-"Standard Methods for the Examination of Water & Wastewater", 19th ed

EPA- "Methods for Chemical Analysis for Water and Wastes", USEPA

MRL-"Method Reporting Limit"

\* Accreditation

A- Waterlab Corporation, ORELAP 100039

The results relate only to the parameters tested or to the sample as received by the laboratory.

This report shall not be reproduced except in full, without the written approval of Waterlab Corporation.

Approved by: \_\_\_\_\_



## TEST REPORT

2603 - 12th Street, SE  
Salem, OR 97302  
Voice: (503) 363-0473  
FAX: (503) 363-8900

TO: Community Action Headstart / Ken Hamlin  
2475 Center St NE  
Salem, OR 97301

6/13/2022

COMACTHS

PO#:

### Collection Information

Date: 5/21/2022  
Time: 0715  
By: James Pilcher  
Lab #: 20220523-140  
Location: Lncstr CR3 AdultSink

### Lab Receipt Information

5/23/2022  
0955  
SW

### Case Narrative

The analyses were performed according to the guidelines in the WATERLAB Corp Quality Assurance Program. This report contains analytical results for the sample(s) as received by the laboratory.

WATERLAB Corp certifies that this report is in compliance with the requirements of NELAP. No unusual difficulties were experienced during analysis of this batch except as noted below or qualified with data flags on the reports.

Analyte	Method	Acc*	Results	Qual	MRL	Units	EPA Limit	Analysis	
								Date	Time
Lead / Schools	SM3113 B	A	1.76		1	ppb	15	6/10/2022	bem

ND- No Detection at @ MRL

SM-"Standard Methods for the Examination of Water & Wastewater", 19th ed

EPA- "Methods for Chemical Analysis for Water and Wastes", USEPA

MRL-"Method Reporting Limit"

\* Accreditation

A- Waterlab Corporation, ORELAP 100039

The results relate only to the parameters tested or to the sample as received by the laboratory.

This report shall not be reproduced except in full, without the written approval of Waterlab Corporation.

Approved by: \_\_\_\_\_



## TEST REPORT

TO: Community Action Headstart / Ken Hamlin  
2475 Center St NE  
Salem, OR 97301

6/13/2022

COMACTHS

PO#:

### Collection Information

Date: 5/21/2022  
Time: 0710  
By: James Pilcher  
Lab #: 20220523-141  
Location: Lncstr CR3 ToilSinkL

### Lab Receipt Information

5/23/2022  
0955  
SW

### Case Narrative

The analyses were performed according to the guidelines in the WATERLAB Corp Quality Assurance Program. This report contains analytical results for the sample(s) as received by the laboratory.

WATERLAB Corp certifies that this report is in compliance with the requirements of NELAP. No unusual difficulties were experienced during analysis of this batch except as noted below or qualified with data flags on the reports.

Analyte	Method	Acc*	Results	Qual	MRL	Units	EPA Limit	Analysis	
								Date Time	Tech
Lead / Schools	SM3113 B	A	ND		1	ppb	15	6/10/2022	bem

ND- No Detection at @ MRL

SM-"Standard Methods for the Examination of Water & Wastewater", 19th ed

EPA- "Methods for Chemical Analysis for Water and Wastes", USEPA

MRL-"Method Reporting Limit"

\* Accreditation

A- Waterlab Corporation, ORELAP 100039

The results relate only to the parameters tested or to the sample as received by the laboratory.

This report shall not be reproduced except in full, without the written approval of Waterlab Corporation.

Approved by: \_\_\_\_\_



## TEST REPORT

TO: Community Action Headstart / Ken Hamlin  
2475 Center St NE  
Salem, OR 97301

6/13/2022

COMACTHS

PO#:

### Collection Information

Date: 5/21/2022  
Time: 0711  
By: James Pilcher  
Lab #: 20220523-142  
Location: Lncstr CR3 ToilSinkR

### Lab Receipt Information

5/23/2022  
0955  
SW

### Case Narrative

The analyses were performed according to the guidelines in the WATERLAB Corp Quality Assurance Program. This report contains analytical results for the sample(s) as received by the laboratory.

WATERLAB Corp certifies that this report is in compliance with the requirements of NELAP. No unusual difficulties were experienced during analysis of this batch except as noted below or qualified with data flags on the reports.

Analyte	Method	Acc*	Results	Qual	MRL	Units	EPA Limit	Analysis	
								Date	Time
Lead / Schools	SM3113 B	A	1.94		1	ppb	15	6/10/2022	bem

ND- No Detection at @ MRL

SM-"Standard Methods for the Examination of Water & Wastewater", 19th ed

EPA- "Methods for Chemical Analysis for Water and Wastes", USEPA

MRL-"Method Reporting Limit"

\* Accreditation

A- Waterlab Corporation, ORELAP 100039

The results relate only to the parameters tested or to the sample as received by the laboratory.

This report shall not be reproduced except in full, without the written approval of Waterlab Corporation.

Approved by: \_\_\_\_\_

