

WATERLAB CORP.

2603 12th Street SE
Salem, OR 97302

Date/Time: 05232022 09:55

Relinquished

Correct Container / N
Correct Volume / N
Hold Time / N

Rec'd By: SW

By: _____ Signature _____ Printed Name _____

SEND RESULTS TO:

Co. Name S.A. HS
Address: 2475 Cewter St NE
City: Salem State: OR
Zip Code: 97301 Phone: 503 508 8206

SEND BILL TO:

Name: _____
Address: _____
City: _____ State: _____
Zip Code: _____ Phone: _____

PROJECT: Lead

#27/bottle sw

COLLECTED BY: C. Greg S. / 1150

TEST	Pb, [redacted]	Pb, [redacted]	Pb, [redacted]	Pb, [redacted]	Pb, [redacted]
DATE	05/22/22	05/21/22	05/21/22	05/21/22	05/21/22
TIME	2:30 pm	2:30 pm	2:45 pm	2:45 pm	2:45 pm
SOURCE	Santiam Classroom Childrens Restroom Right	Santiam Classroom Childrens Restroom Left	Santiam kitchen hand wash sink	Santiam kitchen Hand wash sink	Santiam kitchen TRIP/sink
AB #	20220523-028	20220523-029	20220523-030	20220523-031	20220523-032

TEST	Pb, [redacted]	Pb, [redacted]	Pb, [redacted]	Pb, [redacted]	Pb, [redacted]
DATE					
TIME					
SOURCE					
AB #					

Santiam

TEST REPORT

TO: Community Action Headstart / Ken Hamlin
2475 Center St NE
Salem, OR 97301

06/13/2022

COMACTHS

PO#:

Collection Information

Date: 05/21/2022
Time: 1430
By: Greg Ellison
Lab #: 20220523-028
Location: Santiam CR ChildRR R

Lab Receipt Information

05/23/2022
0955
SW

Case Narrative

The analyses were performed according to the guidelines in the WATERLAB Corp Quality Assurance Program. This report contains analytical results for the sample(s) as received by the laboratory.

WATERLAB Corp certifies that this report is in compliance with the requirements of NELAP. No unusual difficulties were experienced during analysis of this batch except as noted below or qualified with data flags on the reports.

Analyte	Method	Acc*	Results	Qual	MRL	Units	EPA Limit	Analysis	
								Date	Time
Lead / Schools	SM3113 B	A	ND		1	ppb	15	06/13/2022	bern

ND- No Detection at @ MRL

SM-"Standard Methods for the Examination of Water & Wastewater", 19th ed

EPA- "Methods for Chemical Analysis for Water and Wastes", USEPA

MRL-"Method Reporting Limit"

* Accreditation

A- Waterlab Corporation, ORELAP 100039

The results relate only to the parameters tested or to the sample as received by the laboratory.

This report shall not be reproduced except in full, without the written approval of Waterlab Corporation.

Approved by: _____



TEST REPORT

TO: Community Action Headstart / Ken Hamlin
2475 Center St NE
Salem, OR 97301

6/13/2022

COMACTHS

PO#:

Collection Information

Date: 5/21/2022
Time: 1430
By: Greg Ellison
Lab #: 20220523-029
Location: Santiam CR ChildRR L

Lab Receipt Information

5/23/2022
0955
SW

Case Narrative

The analyses were performed according to the guidelines in the WATERLAB Corp Quality Assurance Program. This report contains analytical results for the sample(s) as received by the laboratory.

WATERLAB Corp certifies that this report is in compliance with the requirements of NELAP. No unusual difficulties were experienced during analysis of this batch except as noted below or qualified with data flags on the reports.

Analyte	Method	Acc*	Results	Qual	MRL	Units	EPA Limit	Analysis	
								Date	Time
Lead / Schools	SM3113 B	A	ND		1	ppb	15	6/6/2022	BEM

ND- No Detection at @ MRL

SM-"Standard Methods for the Examination of Water & Wastewater", 19th ed

EPA- "Methods for Chemical Analysis for Water and Wastes", USEPA

MRL-"Method Reporting Limit"

* Accreditation

A- Waterlab Corporation, ORELAP 100039

The results relate only to the parameters tested or to the sample as received by the laboratory.

This report shall not be reproduced except in full, without the written approval of Waterlab Corporation.

Approved by: _____



TEST REPORT

TO: Community Action Headstart / Ken Hamlin
2475 Center St NE
Salem, OR 97301

6/13/2022

COMACTHS

PO#:

Collection Information

Date: 5/21/2022
Time: 1445
By: Greg Ellison
Lab #: 20220523-030
Location: Santiam Kit HW Sink

Lab Receipt Information

5/23/2022
0955
SW

Case Narrative

The analyses were performed according to the guidelines in the WATERLAB Corp Quality Assurance Program. This report contains analytical results for the sample(s) as received by the laboratory.

WATERLAB Corp certifies that this report is in compliance with the requirements of NELAP. No unusual difficulties were experienced during analysis of this batch except as noted below or qualified with data flags on the reports.

Analyte	Method	Acc*	Results	Qual	MRL	Units	EPA Limit	Analysis	
								Date	Time
Lead / Schools	SM3113 B	A	2.44		1	ppb	15	6/6/2022	BEM

ND- No Detection at @ MRL

SM-"Standard Methods for the Examination of Water & Wastewater", 19th ed

EPA- "Methods for Chemical Analysis for Water and Wastes", USEPA

MRL-"Method Reporting Limit"

* Accreditation

A- Waterlab Corporation, ORELAP 100039

The results relate only to the parameters tested or to the sample as received by the laboratory.

This report shall not be reproduced except in full, without the written approval of Waterlab Corporation.

Approved by: _____



TEST REPORT

TO: Community Action Headstart / Ken Hamlin
2475 Center St NE
Salem, OR 97301

6/13/2022

COMACTHS

PO#:

Collection Information

Date: 5/21/2022
Time: 1445
By: Greg Ellison
Lab #: 20220523-031
Location: Santiam Kit Tub Sink

Lab Receipt Information

5/23/2022
0955
SW

Case Narrative

The analyses were performed according to the guidelines in the WATERLAB Corp Quality Assurance Program. This report contains analytical results for the sample(s) as received by the laboratory.

WATERLAB Corp certifies that this report is in compliance with the requirements of NELAP. No unusual difficulties were experienced during analysis of this batch except as noted below or qualified with data flags on the reports.

Analyte	Method	Acc*	Results	Qual	MRL	Units	EPA Limit	Analysis	
								Date	Time
Lead / Schools	SM3113 B	A	1.20		1	ppb	15	6/6/2022	BEM

ND- No Detection at @ MRL

SM-"Standard Methods for the Examination of Water & Wastewater", 19th ed

EPA- "Methods for Chemical Analysis for Water and Wastes", USEPA

MRL-"Method Reporting Limit"

* Accreditation

A- Waterlab Corporation, ORELAP 100039

The results relate only to the parameters tested or to the sample as received by the laboratory.

This report shall not be reproduced except in full, without the written approval of Waterlab Corporation.

Approved by: _____



TEST REPORT

TO: Community Action Headstart / Ken Hamlin
2475 Center St NE
Salem, OR 97301

6/13/2022

COMACTHS

PO#:

Collection Information

Date: 5/21/2022
Time: 1445
By: Greg Ellison
Lab #: 20220523-032
Location: Santiam Kit TripSink

Lab Receipt Information

5/23/2022
0955
SW

Case Narrative

The analyses were performed according to the guidelines in the WATERLAB Corp Quality Assurance Program. This report contains analytical results for the sample(s) as received by the laboratory.

WATERLAB Corp certifies that this report is in compliance with the requirements of NELAP. No unusual difficulties were experienced during analysis of this batch except as noted below or qualified with data flags on the reports.

Analyte	Method	Acc*	Results	Qual	MRL	Units	EPA Limit	Analysis	
								Date	Time
Lead / Schools	SM3113 B	A	2.03		1	ppb	15	6/6/2022	BEM

ND- No Detection at @ MRL

SM-"Standard Methods for the Examination of Water & Wastewater", 19th ed

EPA- "Methods for Chemical Analysis for Water and Wastes", USEPA

MRL-"Method Reporting Limit"

* Accreditation

A- Waterlab Corporation, ORELAP 100039

The results relate only to the parameters tested or to the sample as received by the laboratory.

This report shall not be reproduced except in full, without the written approval of Waterlab Corporation.

Approved by: _____

