

WATERLAB CORP.

2603 12th Street SE
Salem, OR 97302

Date/Time: 05/23/2022 09:55

Correct Contalner Y / N
Correct Volume Y / N
Hold Time Y / N

Relinquished

By: _____ Signature _____ Printed Name _____

Rec'd By: _____

Community Action HEADSTART

SEND RESULTS TO:

Co. Name: **CAHS - KEN HAMLIN**
Address: **4775 CENTER ST. NE**
City: **SALVEM** State: **OR**
Zip Code: **97301** Phone: **503-508-8206**

SEND BILL TO:

Name: _____
Address: _____
City: _____ State: _____
Zip Code: _____ Phone: _____

PROJECT: Lead

#271 ^{bas data} _{SW}

COLLECTED BY: _____

TEST	Pb, [redacted]	Pb, [redacted]	Pb, [redacted]	Pb, [redacted]
DATE	5-22-22	5-22-22	5-22-22	5-22-22
TIME	109 pm	110 pm	112 pm	113 pm
SOURCE	KIT. HAND SINK	KIT. SINK	ADULT BATH SINK #1	KIDS SINK #2
AB #	20220523-060	20220523-061	20220523-062	20220523-063-064

TEST	Pb, [redacted]	Pb, [redacted]	Pb, [redacted]	Pb, [redacted]
DATE				
TIME				
SOURCE				
AB #				

WILBUR

TEST REPORT

TO: Community Action Headstart / Ken Hamlin
2475 Center St NE
Salem, OR 97301

6/13/2022

COMACTHS

PO#:

Collection Information

Date: 5/22/2022
Time: 1309
By: Tom Devine
Lab #: 20220523-060
Location: Wilbur Kit Hand Sink

Lab Receipt Information

5/23/2022
0955
SW

Case Narrative

The analyses were performed according to the guidelines in the WATERLAB Corp Quality Assurance Program. This report contains analytical results for the sample(s) as received by the laboratory.

WATERLAB Corp certifies that this report is in compliance with the requirements of NELAP. No unusual difficulties were experienced during analysis of this batch except as noted below or qualified with data flags on the reports.

Analyte	Method	Acc*	Results	Qual	MRL	Units	EPA Limit	Analysis	
								Date	Time
Lead / Schools	SM3113 B	A	1.37		1	ppb	15	6/6/2022	BEM

ND- No Detection at @ MRL

SM-"Standard Methods for the Examination of Water & Wastewater", 19th ed

EPA- "Methods for Chemical Analysis for Water and Wastes", USEPA

MRL-"Method Reporting Limit"

* Accreditation

A- Waterlab Corporation, ORELAP 100039

The results relate only to the parameters tested or to the sample as received by the laboratory.

This report shall not be reproduced except in full, without the written approval of Waterlab Corporation.

Approved by: _____



TEST REPORT

TO: Community Action Headstart / Ken Hamlin
2475 Center St NE
Salem, OR 97301

6/13/2022

COMACTHS

PO#:

Collection Information

Date: 5/22/2022
Time: 1310
By: Tom Devine
Lab #: 20220523-061
Location: Wilbur Kit Sink

Lab Receipt Information

5/23/2022
0955
SW

Case Narrative

The analyses were performed according to the guidelines in the WATERLAB Corp Quality Assurance Program. This report contains analytical results for the sample(s) as received by the laboratory.

WATERLAB Corp certifies that this report is in compliance with the requirements of NELAP. No unusual difficulties were experienced during analysis of this batch except as noted below or qualified with data flags on the reports.

Analyte	Method	Acc*	Results	Qual	MRL	Units	EPA Limit	Analysis Date Time	Tech
Lead / Schools	SM3113 B	A	ND		1	ppb	15	6/10/2022	BEM

ND- No Detection at @ MRL

SM-"Standard Methods for the Examination of Water & Wastewater", 19th ed

EPA- "Methods for Chemical Analysis for Water and Wastes", USEPA

MRL-"Method Reporting Limit"

* Accreditation

A- Waterlab Corporation, ORELAP 100039

The results relate only to the parameters tested or to the sample as received by the laboratory.

This report shall not be reproduced except in full, without the written approval of Waterlab Corporation.

Approved by: _____



TEST REPORT

TO: Community Action Headstart / Ken Hamlin
2475 Center St NE
Salem, OR 97301

6/13/2022

COMACTHS

PO#:

Collection Information

Date: 5/22/2022
Time: 1311
By: Tom Devine
Lab #: 20220523-062
Location: Wilbur Adult RR Sink

Lab Receipt Information

5/23/2022
0955
SW

Case Narrative

The analyses were performed according to the guidelines in the WATERLAB Corp Quality Assurance Program. This report contains analytical results for the sample(s) as received by the laboratory.

WATERLAB Corp certifies that this report is in compliance with the requirements of NELAP. No unusual difficulties were experienced during analysis of this batch except as noted below or qualified with data flags on the reports.

Analyte	Method	Acc*	Results	Qual	MRL	Units	EPA Limit	Analysis	
								Date	Time
Lead / Schools	SM3113 B	A	8.30		1	ppb	15	6/6/2022	BEM

ND- No Detection at @ MRL

SM-"Standard Methods for the Examination of Water & Wastewater", 19th ed

EPA- "Methods for Chemical Analysis for Water and Wastes", USEPA

MRL-"Method Reporting Limit"

* Accreditation

A- Waterlab Corporation, ORELAP 100039

The results relate only to the parameters tested or to the sample as received by the laboratory.

This report shall not be reproduced except in full, without the written approval of Waterlab Corporation.

Approved by: _____



TEST REPORT

TO: Community Action Headstart / Ken Hamlin
2475 Center St NE
Salem, OR 97301

6/13/2022

COMACTHS

PO#:

Collection Information

Date: 5/22/2022
Time: 1312
By: Tom Devine
Lab #: 20220523-063
Location: Wilbur 1 Kids Sink

Lab Receipt Information

5/23/2022
0955
SW

Case Narrative

The analyses were performed according to the guidelines in the WATERLAB Corp Quality Assurance Program. This report contains analytical results for the sample(s) as received by the laboratory.

WATERLAB Corp certifies that this report is in compliance with the requirements of NELAP. No unusual difficulties were experienced during analysis of this batch except as noted below or qualified with data flags on the reports.

Analyte	Method	Acc*	Results	Qual	MRL	Units	EPA Limit	Analysis	
								Date	Time
Lead / Schools	SM3113 B	A	3.54		1	ppb	15	6/6/2022	BEM

ND- No Detection at @ MRL

SM-"Standard Methods for the Examination of Water & Wastewater", 19th ed

EPA- "Methods for Chemical Analysis for Water and Wastes", USEPA

MRL-"Method Reporting Limit"

* Accreditation

A- Waterlab Corporation, ORELAP 100039

The results relate only to the parameters tested or to the sample as received by the laboratory.

This report shall not be reproduced except in full, without the written approval of Waterlab Corporation.

Approved by: _____



TEST REPORT

TO: Community Action Headstart / Ken Hamlin
2475 Center St NE
Salem, OR 97301

6/13/2022

COMACTHS

PO#:

Collection Information

Date: 5/22/2022
Time: 1313
By: Tom Devine
Lab #: 20220523-064
Location: Wilbur 2 Kids Sink

Lab Receipt Information

5/23/2022
0955
SW

Case Narrative

The analyses were performed according to the guidelines in the WATERLAB Corp Quality Assurance Program. This report contains analytical results for the sample(s) as received by the laboratory.

WATERLAB Corp certifies that this report is in compliance with the requirements of NELAP. No unusual difficulties were experienced during analysis of this batch except as noted below or qualified with data flags on the reports.

Analyte	Method	Acc*	Results	Qual	MRL	Units	EPA Limit	Analysis	
								Date	Time
Lead / Schools	SM3113 B	A	ND		1	ppb	15	6/6/2022	BEM

ND- No Detection at @ MRL

SM-"Standard Methods for the Examination of Water & Wastewater", 19th ed

EPA- "Methods for Chemical Analysis for Water and Wastes", USEPA

MRL-"Method Reporting Limit"

* Accreditation

A- Waterlab Corporation, ORELAP 100039

The results relate only to the parameters tested or to the sample as received by the laboratory.

This report shall not be reproduced except in full, without the written approval of Waterlab Corporation.

Approved by: _____

