

# WATERLAB CORP.

2603 12<sup>th</sup> Street SE  
Salem, OR 97302

Date/Time: 05232022 09:55

Relinquished

Correct ContAINER Y / N  
Correct Volume Y / N  
Hold Time Y / N

Rec'd By: \_\_\_\_\_

By: \_\_\_\_\_  
Signature

Printed Name

*Community Action Head Start*

SEND RESULTS TO:

Co. Name: CAHS - Ken Hamlin  
Address: 2475 Center St. NE  
City: Salem State: Oregon  
Zip Code: 97301 Phone: 503-508-8206

SEND BILL TO:

Name: \_\_\_\_\_  
Address: \_\_\_\_\_  
City: \_\_\_\_\_ State: \_\_\_\_\_  
Zip Code: \_\_\_\_\_ Phone: \_\_\_\_\_

PROJECT: Lead #27/bottle

COLLECTED BY: James Pletcher

TEST DATE TIME SOURCE AB #	1	2	3	4	5
5/21/22	Pb	Pb	Pb	Pb	Pb
12:49	Woodburn Office BR SINK	12:53 WBRN Kitchen Dish SINK	12:56 WBRN HITCHEN HAND SINK	13:02 WBRN CLASS ROOM ADULT SINK	13:00 1303 WBRN CLASS ROOM CHILD LEFT
20220523-131	20220523-132	20220523-133	20220523-134	20220523-135	

*OR bottles 5-23-22*

EST DATE TIME SOURCE AB #	1	2	3	4	5
5/21/22	Pb	Pb	Pb	Pb	Pb
1310	WBRN CLASS ROOM				
CHILD RIGHT					
20220523-136					

*WOODBURN*

## TEST REPORT

**TO: Community Action Headstart / Ken Hamlin**  
**2475 Center St NE**  
**Salem, OR 97301**

06/20/2022

COMACTHS

PO#:

### Collection Information

Date: 06/16/2022  
Time: 0725  
By: James Pilcher  
Lab #: 20220616-036  
Location: Woodburn Class roomchild sink left

### Lab Receipt Information

06/16/2022  
1341  
SW

### Case Narrative

The analyses were performed according to the guidelines in the WATERLAB Corp Quality Assurance Program. This report contains analytical results for the sample(s) as received by the laboratory.

WATERLAB Corp certifies that this report is in compliance with the requirements of NELAP. No unusual difficulties were experienced during analysis of this batch except as noted below or qualified with data flags on the reports.

Analyte	Method	Acc*	Results	Qual	MRL	Units	EPA Limit	Analysis	
								Date	Time
Lead / Schools	SM3113 B	A	ND		1	ppb	15	06/17/2022	bem

ND- No Detection at @ MRL

SM-"Standard Methods for the Examination of Water & Wastewater", 19th ed

EPA- "Methods for Chemical Analysis for Water and Wastes", USEPA

MRL-"Method Reporting Limit"

\* Accreditation

A- Waterlab Corporation, ORELAP 100039

The results relate only to the parameters tested or to the sample as received by the laboratory.

This report shall not be reproduced except in full, without the written approval of Waterlab Corporation.

Approved by: \_\_\_\_\_



## TEST REPORT

TO: Community Action Headstart / Ken Hamlin  
2475 Center St NE  
Salem, OR 97301

6/13/2022

COMACTHS

PO#:

### Collection Information

Date: 5/21/2022  
Time: 1253  
By: James Pilcher  
Lab #: 20220523-132  
Location: Wbrn Kit Dish Sink

### Lab Receipt Information

5/23/2022  
0955  
SW

### Case Narrative

The analyses were performed according to the guidelines in the WATERLAB Corp Quality Assurance Program. This report contains analytical results for the sample(s) as received by the laboratory.

WATERLAB Corp certifies that this report is in compliance with the requirements of NELAP. No unusual difficulties were experienced during analysis of this batch except as noted below or qualified with data flags on the reports.

Analyte	Method	Acc*	Results	Qual	MRL	Units	EPA Limit	Analysis	
								Date	Time
Lead / Schools	SM3113 B	A	ND		1	ppb	15	6/10/2022	bem

ND- No Detection at @ MRL

SM-"Standard Methods for the Examination of Water & Wastewater", 19th ed

EPA- "Methods for Chemical Analysis for Water and Wastes", USEPA

MRL-"Method Reporting Limit"

\* Accreditation

A- Waterlab Corporation, ORELAP 100039

The results relate only to the parameters tested or to the sample as received by the laboratory.

This report shall not be reproduced except in full, without the written approval of Waterlab Corporation.

Approved by: 

## TEST REPORT

TO: Community Action Headstart / Ken Hamlin  
2475 Center St NE  
Salem, OR 97301

6/13/2022

COMACTHS

PO#:

### Collection Information

Date: 5/21/2022  
Time: 1256  
By: James Pilcher  
Lab #: 20220523-133  
Location: Wbrn Kit Hand Sink

### Lab Receipt Information

5/23/2022  
0955  
SW

### Case Narrative

The analyses were performed according to the guidelines in the WATERLAB Corp Quality Assurance Program. This report contains analytical results for the sample(s) as received by the laboratory.

WATERLAB Corp certifies that this report is in compliance with the requirements of NELAP. No unusual difficulties were experienced during analysis of this batch except as noted below or qualified with data flags on the reports.

Analyte	Method	Acc*	Results	Qual	MRL	Units	EPA Limit	Analysis	
								Date	Time
Lead / Schools	SM3113 B	A	ND		1	ppb	15	6/10/2022	bem

ND- No Detection at @ MRL

SM-"Standard Methods for the Examination of Water & Wastewater", 19th ed

EPA- "Methods for Chemical Analysis for Water and Wastes", USEPA

MRL-"Method Reporting Limit"

\* Accreditation

A- Waterlab Corporation, ORELAP 100039

The results relate only to the parameters tested or to the sample as received by the laboratory.

This report shall not be reproduced except in full, without the written approval of Waterlab Corporation.

Approved by: \_\_\_\_\_



## TEST REPORT

2603 - 12th Street, SE  
Salem, OR 97302  
Voice: (503) 363-0473  
FAX: (503) 363-8900

TO: Community Action Headstart / Ken Hamlin  
2475 Center St NE  
Salem, OR 97301

6/13/2022

COMACTHS

PO#:

### Collection Information

Date: 5/21/2022  
Time: 1302  
By: James Pilcher  
Lab #: 20220523-134  
Location: Wbrn CR Adult Sink

### Lab Receipt Information

5/23/2022  
0955  
SW

### Case Narrative

The analyses were performed according to the guidelines in the WATERLAB Corp Quality Assurance Program. This report contains analytical results for the sample(s) as received by the laboratory.

WATERLAB Corp certifies that this report is in compliance with the requirements of NELAP. No unusual difficulties were experienced during analysis of this batch except as noted below or qualified with data flags on the reports.

Analyte	Method	Acc*	Results	Qual	MRL	Units	EPA Limit	Analysis	
								Date	Time
Lead / Schools	SM3113 B	A	9.62		1	ppb	15	6/10/2022	bem

ND- No Detection at @ MRL

SM-"Standard Methods for the Examination of Water & Wastewater", 19th ed

EPA- "Methods for Chemical Analysis for Water and Wastes", USEPA

MRL-"Method Reporting Limit"

\* Accreditation

A- Waterlab Corporation, ORELAP 100039

The results relate only to the parameters tested or to the sample as received by the laboratory.

This report shall not be reproduced except in full, without the written approval of Waterlab Corporation.

Approved by: \_\_\_\_\_



## TEST REPORT

**TO: Community Action Headstart / Ken Hamlin**  
**2475 Center St NE**  
**Salem, OR 97301**

06/20/2022

COMACTHS

PO#:

### Collection Information

Date: 06/16/2022  
Time: 0729  
By: James Pilcher  
Lab #: 20220616-037  
Location: Woodburn Office Bathroom sink

### Lab Receipt Information

06/16/2022  
1341  
SW

### Case Narrative

The analyses were performed according to the guidelines in the WATERLAB Corp Quality Assurance Program. This report contains analytical results for the sample(s) as received by the laboratory.

WATERLAB Corp certifies that this report is in compliance with the requirements of NELAP. No unusual difficulties were experienced during analysis of this batch except as noted below or qualified with data flags on the reports.

Analyte	Method	Acc*	Results	Qual	MRL	Units	EPA Limit	Analysis	
								Date	Time
Lead / Schools	SM3113 B	A	ND		1	ppb	15	06/17/2022	bem

ND- No Detection at @ MRL

SM-"Standard Methods for the Examination of Water & Wastewater", 19th ed

EPA- "Methods for Chemical Analysis for Water and Wastes", USEPA

MRL-"Method Reporting Limit"

\* Accreditation

A- Waterlab Corporation, ORELAP 100039

The results relate only to the parameters tested or to the sample as received by the laboratory.

This report shall not be reproduced except in full, without the written approval of Waterlab Corporation.

Approved by: \_\_\_\_\_



## TEST REPORT

TO: Community Action Headstart / Ken Hamlin  
2475 Center St NE  
Salem, OR 97301

6/13/2022

COMACTHS

PO#:

### Collection Information

Date: 5/21/2022  
Time: 1300  
By: James Pilcher  
Lab #: 20220523-136  
Location: Wbm CR Child Right

### Lab Receipt Information

5/23/2022  
0955  
SW

### Case Narrative

The analyses were performed according to the guidelines in the WATERLAB Corp Quality Assurance Program. This report contains analytical results for the sample(s) as received by the laboratory.

WATERLAB Corp certifies that this report is in compliance with the requirements of NELAP. No unusual difficulties were experienced during analysis of this batch except as noted below or qualified with data flags on the reports.

Analyte	Method	Acc*	Results	Qual	MRL	Units	EPA Limit	Analysis	
								Date	Time
Lead / Schools	SM3113 B	A	11.6		1	ppb	15	6/6/2022	bern

ND- No Detection at @ MRL

SM-"Standard Methods for the Examination of Water & Wastewater", 19th ed

EPA- "Methods for Chemical Analysis for Water and Wastes", USEPA

MRL-"Method Reporting Limit"

\* Accreditation

A- Waterlab Corporation, ORELAP 100039

The results relate only to the parameters tested or to the sample as received by the laboratory.

This report shall not be reproduced except in full, without the written approval of Waterlab Corporation.

Approved by: \_\_\_\_\_

