

2603 - 12th Street, SE Salem, OR 97302 Voice: (503) 363-0473 FAX: (503) 363-8900

TO: Community Action Headstart / Ken Hamlin

2475 Center St NE Salem, OR 97301

9/29/2022

COMACTHS

PO#:

Collection Information

Date: 9/22/2022 Time: 1230

Ken Hamlin By:

Lab #: Location: 20220923-009 Chemawa #1

Lab Receipt Information

9/23/2022 1019 MM

Case Narrative

The analyses were performed according to the guidelines in the WATERLAB Corp Quality Assurance Program. This report contains analytical results for the sample(s) as received by the laboratory.

WATERLAB Corp certifies that this report is in compliance with the requirements of NELAP. No unusual difficulties were experienced during analysis of this batch except as noted below or qualified with data flags on the reports.

| | | | | | | | EPA | Analysis | |
|----------------|----------|-----|-----------|------|-----|-------|-------|-----------|------|
| Analyte | Method | Acc | * Results | Qual | MRL | Units | Limit | Date Time | Tech |
| Lead / Schools | SM3113 B | Α | ND | | 1 | ppb | 15 | 9/28/2022 | bem |

ND- No Detection at @ MRL

SM-"Standard Methods for the Examination of Water & Wastewater", 19th ed EPA- "Methods for Chemical Analysis for Water and Wastes", USEPA

MRL-"Method Reporting Limit"

* Accreditation

A- Waterlab Corporation, ORELAP 100039

The results relate only to the parameters tested or to the sample as received by the laboratory.

This report shall not be reproduced except in full, without the written approval of Waterlab Corporation.

Approved by: Stir E. Myers



2603 - 12th Street, SE Salem, OR 97302 Voice: (503) 363-0473 FAX: (503) 363-8900

TO: Community Action Headstart / Ken Hamlin

9/13/2022

2475 Center St NE Salem, OR 97301

COMACTHS

PO#:

Collection Information

Lab Receipt Information

9/7/2022 1435 SW

Date: 9/7/2022 Time: 1115

By: Ken Hamlin

Lab #:

20220907-034

Location: #2

Case Narrative

The analyses were performed according to the guidelines in the WATERLAB Corp Quality Assurance Program. This report contains analytical results for the sample(s) as received by the laboratory.

WATERLAB Corp certifies that this report is in compliance with the requirements of NELAP. No unusual difficulties were experienced during analysis of this batch except as noted below or qualified with data flags on the reports.

| | | | EPA | | EPA | Analysis | | | |
|----------------|----------|------|---------|------|-----|----------|-------|-----------|------|
| Analyte | Method | Acc* | Results | Qual | MRL | Units | Limit | Date Time | Tech |
| Lead / Schools | SM3113 B | Α | 3.05 | | 1 | ppb | 15 | 9/11/2022 | bem |

ND- No Detection at @ MRL SM-"Standard Methods for the Examination of Water & Wastewater",19th ed EPA- "Methods for Chemical Analysis for Water and Wastes",USEPA MRL-"Method Reporting Limit" * Accreditation A- Waterlab Corporation, ORELAP 100039 The results relate only to the parameters tested or to the sample as received by the laboratory.

This report shall not be reproduced except in full, without the written approval of Waterlab Corporation.

| | h |
|--------------|---|
| Approved by: | |



2603 - 12th Street, SE Salem, OR 97302 Voice: (503) 363-0473 FAX: (503) 363-8900

TO: Community Action Headstart / Ken Hamlin

9/13/2022

2475 Center St NE Salem, OR 97301

COMACTHS

PO#:

Collection Information

Lab Receipt Information

Date: 9/7/2022 Time: 1115

9/7/2022 1435 SW

Ken Hamlin By:

Lab #:

20220907-035

Location:

#3

Case Narrative

The analyses were performed according to the guidelines in the WATERLAB Corp Quality Assurance Program. This report contains analytical results for the sample(s) as received by the laboratory.

WATERLAB Corp certifies that this report is in compliance with the requirements of NELAP. No unusual difficulties were experienced during analysis of this batch except as noted below or qualified with data flags on the reports.

| | | | | A-17- | | | EPA | Analysis | |
|----------------|----------|------|---------|-------|-----|-------|-------|-----------|------|
| | Method | Acc* | Results | Qual | MRL | Units | Limit | Date Time | Tech |
| Lead / Schools | SM3113 B | Α | 2.34 | | 1 | ppb | 15 | 9/11/2022 | bem |

ND- No Detection at @ MRL

SM-"Standard Methods for the Examination of Water & Wastewater",19th ed EPA- "Methods for Chemical Analysis for Water and Wastes" USEPA

MRL-"Method Reporting Limit"

* Accreditation

A- Waterlab Corporation, ORELAP 100039

The results relate only to the parameters tested or to the sample as received by the laboratory.

This report shall not be reproduced except in full, without the written approval of Waterlab Corporation.

| Approved by: | |
|--------------|--|

1.



2603 - 12th Street, SE Salem, OR 97302 Voice: (503) 363-0473 FAX: (503) 363-8900

TO: Community Action Headstart / Ken Hamlin

2475 Center St NE Salem, OR 97301

9/13/2022

COMACTHS

PO#:

Collection Information

Date: 9/7/2022 Time: 1115

Ken Hamlin By:

Lab #:

20220907-036

Location:

#4

Lab Receipt Information

9/7/2022 1435 SW

Case Narrative

The analyses were performed according to the guidelines in the WATERLAB Corp Quality Assurance Program. This report contains analytical results for the sample(s) as received by the laboratory.

WATERLAB Corp certifies that this report is in compliance with the requirements of NELAP. No unusual difficulties were experienced during analysis of this batch except as noted below or qualified with data flags on the reports.

| | | | | | | | EPA | Analysis | |
|----------------|----------|------|---------|------|-----|-------|-------|-----------|------|
| Analyte | Method | Acc* | Results | Qual | MRL | Units | Limit | Date Time | Tech |
| Lead / Schools | SM3113 B | Α | 2.00 | | 1 | ppb | 15 | 9/11/2022 | bem |

ND- No Detection at @ MRL SM-"Standard Methods for the Examination of Water & Wastewater",19th ed EPA- "Methods for Chemical Analysis for Water and Wastes", USEPA MRL-"Method Reporting Limit" * Accreditation A- Waterlab Corporation, ORELAP 100039

The results relate only to the parameters tested or to the sample as received by the laboratory.

This report shall not be reproduced except in full, without the written approval of Waterlab Corporation.

| | R |
|--------------|---|
| Approved by: | |



2603 - 12th Street, SE Salem, OR 97302 Voice: (503) 363-0473 FAX: (503) 363-8900

TO: Community Action Headstart / Ken Hamlin

2475 Center St NE

9/13/2022

Salem, OR 97301

COMACTHS

PO#:

Collection Information

Date: 9/7/2022 Time: 1115

By: Ken Hamlin

Lab #:

20220907-037

Location:

#5

Lab Receipt Information

9/7/2022 1435 SW

Case Narrative

The analyses were performed according to the guidelines in the WATERLAB Corp Quality Assurance Program. This report contains analytical results for the sample(s) as received by the laboratory.

WATERLAB Corp certifies that this report is in compliance with the requirements of NELAP. No unusual difficulties were experienced during analysis of this batch except as noted below or qualified with data flags on the reports.

| | | | | | | | EPA | Analysis | |
|----------------|----------|------|---------|------|-----|-------|-------|-----------|------|
| Analyte | Method | Acc* | Results | Qual | MRL | Units | Limit | Date Time | Tech |
| Lead / Schools | SM3113 B | Α | 2.12 | | 1 | ppb | 15 | 9/11/2022 | bem |

ND- No Detection at @ MRL SM-"Standard Methods for the Examination of Water & Wastewater",19th ed EPA- "Methods for Chemical Analysis for Water and Wastes",USEPA MRL-"Method Reporting Limit" * Accreditation A- Waterlab Corporation, ORELAP 100039 The results relate only to the parameters tested or to the sample as received by the laboratory.

This report shall not be reproduced except in full, without the written approval of Waterlab Corporation.

| | M |
|--------------|---|
| Approved by: | |



2603 - 12th Street, SE Salem, OR 97302 Voice: (503) 363-0473 FAX: (503) 363-8900

TO: Community Action Headstart / Ken Hamlin

9/13/2022

2475 Center St NE Salem, OR 97301

COMACTHS

PO#:

Collection Information

Lab Receipt Information

9/7/2022 1435 SW

Date: 9/7/2022 Time: 1115

Ken Hamlin By: Lab #:

20220907-038

Location:

Case Narrative

The analyses were performed according to the guidelines in the WATERLAB Corp Quality Assurance Program. This report contains analytical results for the sample(s) as received by the laboratory.

WATERLAB Corp certifies that this report is in compliance with the requirements of NELAP. No unusual difficulties were experienced during analysis of this batch except as noted below or qualified with data flags on the reports.

| | | | | | | | EPA | Analysis | |
|----------------|----------|-----|-----------|------|-----|-------|-------|-----------|------|
| Analyte | Method | Acc | * Results | Qual | MRL | Units | Limit | Date Time | Tech |
| Lead / Schools | SM3113 B | Α | 1.81 | | 1 | ppb | 15 | 9/11/2022 | bem |

ND- No Detection at @ MRL SM-"Standard Methods for the Examination of Water & Wastewater",19th ed EPA- "Methods for Chemical Analysis for Water and Wastes", USEPA MRL-"Method Reporting Limit" * Accreditation A- Waterlab Corporation, ORELAP 100039 The results relate only to the parameters tested or to the sample as received by the laboratory.

This report shall not be reproduced except in full, without the written approval of Waterlab Corporation.

Approved by:



2603 - 12th Street, SE Salem, OR 97302 Voice: (503) 363-0473 FAX: (503) 363-8900

TO: Community Action Headstart / Ken Hamlin

2475 Center St NE Salem, OR 97301 9/13/2022

COMACTHS

PO#:

Collection Information

Date: 9/7/2022 Time: 1115

By: Ken

Ken Hamlin

Lab #:

20220907-039

Location: #7

Lab Receipt Information

9/7/2022 1435 SW

Case Narrative

The analyses were performed according to the guidelines in the WATERLAB Corp Quality Assurance Program. This report contains analytical results for the sample(s) as received by the laboratory.

WATERLAB Corp certifies that this report is in compliance with the requirements of NELAP. No unusual difficulties were experienced during analysis of this batch except as noted below or qualified with data flags on the reports.

| | | | | | | | EPA | Analysis | |
|----------------|----------|------|---------|------|-----|-------|-------|-----------|------|
| Analyte | Method | Acc* | Results | Qual | MRL | Units | Limit | Date Time | Tech |
| Lead / Schools | SM3113 B | А | 2.9 | | 1 | ppb | 15 | 9/11/2022 | bem |

ND- No Detection at @ MRL SM-"Standard Methods for the Examination of Water & Wastewater",19th ed EPA- "Methods for Chemical Analysis for Water and Wastes",USEPA MRL-"Method Reporting Limit" * Accreditation A- Waterlab Corporation, ORELAP 100039 The results relate only to the parameters tested or to the sample as received by the laboratory.

This report shall not be reproduced except in full, without the written approval of Waterlab Corporation.

Approved by: _____



2603 - 12th Street, SE Salem, OR 97302 Voice: (503) 363-0473 FAX: (503) 363-8900

TO: Community Action Headstart / Ken Hamlin

2475 Center St NE

Salem, OR 97301

9/13/2022

COMACTHS

PO#:

Collection Information

Date: 9/7/2022 Time: 1115

By: Ken Hamlin

Lab #:

20220907-040

Location:

#8

Lab Receipt Information

9/7/2022 1435 SW

Case Narrative

The analyses were performed according to the guidelines in the WATERLAB Corp Quality Assurance Program. This report contains analytical results for the sample(s) as received by the laboratory.

WATERLAB Corp certifies that this report is in compliance with the requirements of NELAP. No unusual difficulties were experienced during analysis of this batch except as noted below or qualified with data flags on the reports.

| | | | | | | | EPA | Analysis | |
|----------------|----------|------|---------|------|-----|-------|-------|-----------|------|
| Analyte | Method | Acc* | Results | Qual | MRL | Units | Limit | Date Time | Tech |
| Lead / Schools | SM3113 B | Α | 6.82 | | 1 | ppb | 15 | 9/11/2022 | bem |

ND- No Detection at @ MRL SM-"Standard Methods for the Examination of Water & Wastewater",19th ed EPA- "Methods for Chemical Analysis for Water and Wastes",USEPA MRL-"Method Reporting Limit" * Accreditation A- Waterlab Corporation, ORELAP 100039 The results relate only to the parameters tested or to the sample as received by the laboratory.

This report shall not be reproduced except in full, without the written approval of Waterlab Corporation.

| | M | |
|--------------|---|--|
| Approved by: | | |