

TEST REPORT

TO: Community Action Headstart / Ken Hamlin
2475 Center St NE
Salem, OR 97301

12/26/2023

COMACTHS

PO#:

Collection Information

Date: 12/18/2023
Time: 0745
By: Tom Devine
Lab #: 20231218-001
Location: 1205 Wallace Rd NW Salem/ kitchen

Lab Receipt Information

12/18/2023
0833
SW

Case Narrative

The analyses were performed according to the guidelines in the WATERLAB Corp Quality Assurance Program. This report contains analytical results for the sample(s) as received by the laboratory.

WATERLAB Corp certifies that this report is in compliance with the requirements of NELAP. No unusual difficulties were experienced during analysis of this batch except as noted below or qualified with data flags on the reports.

Analyte	Method	Acc*	Results	Qual	MRL	Units	EPA Limit	Analysis	
								Date	Time
Lead / Day Care - RUSH	SM3113 B	A	ND		1	ppb	15	12/21/2023	bem

ND- No Detection at @ MRL

SM-"Standard Methods for the Examination of Water & Wastewater", 19th ed

EPA- "Methods for Chemical Analysis for Water and Wastes", USEPA

MRL-"Method Reporting Limit"

* Accreditation

A- Waterlab Corporation, ORELAP 100039

The results relate only to the parameters tested or to the sample as received by the laboratory.

This report shall not be reproduced except in full, without the written approval of Waterlab Corporation.

Approved by: _____

